A comparative study of two SOFC based cogeneration systems fed by municipal solid waste by means of either the gasifier or digester

Original

A comparative study of two SOFC based cogeneration systems fed by municipal solid waste by means of either the gasifier or digester / Yari, Mortaza; Mehr, Ali Saberi; Mahmoudi, Seyed Mohammad Seyed; Santarelli, Massimo. - In: ENERGY. - ISSN 0360-5442. - 114:(2016), pp. 586-602. [10.1016/j.energy.2016.08.035]

Availability:

This version is available at: 11583/2648246 since: 2016-09-12T16:07:51Z

Publisher:

Elsevier Ltd

Published

DOI:10.1016/j.energy.2016.08.035

Terms of use:

openAccess

This article is made available under terms and conditions as specified in the corresponding bibliographic description in the repository

Publisher copyright

(Article begins on next page)

A comparative study of two SOFC based cogeneration systems fed by municipal solid waste by means of either the gasifier or digester

M. Yari¹, A. S. Mehr^{1,*}, SMS Mahmoudi¹ and M. Santarelli²

1. Faculty of Mechanical Engineering, University of Tabriz, Tabriz, Iran
2. Department of Energy, Politecnico di Torino, C.so Duca degli Abruzzi 24, 10129, Turin, Italy

Abstract

Two new cogeneration systems (producing power and heating) based on solid oxide fuel cell fed by either the syngas or biogas is proposed. The performance of systems is analyzed and compared with each other from the thermodynamic and economic viewpoints. Applying the conservation of mass and energy as well as the exergy and cost balance for each system component and using the engineering equation solver software, the systems are modeled. Through a parametric study, effect of some key variables such as the current density and the stack temperature difference on the systems' performance is investigated. It is found that for power generation, digester based solid oxide fuel cell shows better performance of first law efficiency (40.14% vs 20.31%); however considering the combined power and heating system, the difference becomes less (51.05% vs 58.75%). In addition, it is found that the digester based SOFC is more cost-efficient and has 54% less unit product cost compared to that of the gasifier based system. Results of exergy analysis reveal that the air heat exchangers and the gasifier are the two major sources of irreversibility in the systems. Finally, a method of choosing the systems based on the need and the cost is presented.

Keywords: *SOFC, Biogas, Syngas, Gasifier, Anaerobic Digester, Exergoeconomic, comparative study*

*Corresponding author e-mail: a.s.mehr@tabrizu.ac.ir (Ali Saberi Mehr)

Tel.: +98 41 33392487; fax: +98 41 33354153.

Nomenclature

AD	Anaerobic digester	<i>Subscript and abbreviations</i>	
AHX	Air heat exchanger	0	dead state
D-SOFC	Digester coupled SOFC	1,2,3,...	state points
G-SOFC	Gasifier coupled SOFC		
SOFC	Solid oxide fuel cell	<i>Greek Symbols</i>	
HRSG	Heat recovery steam generator	η_{th}	thermal efficiency
EES	Engineering Equation Solver		
FHX	Fuel heat exchanger	η_{II}	exergy efficiency
FuelB	Fuel blower	η_I	energy efficiency
AirB	Air blower	η_{is}	isentropic efficiency
P	pump		
K	equilibrium constant		
ΔG	Change in Gibbs function		
S	entropy		
h	enthalpy		
$\dot{W}$	Power		
$\dot{Q}$	Heating load		

26

27

28

1. Introduction

Since the world's energy consumption is forecast to rise remarkably during the next two decades, no one can deny the importance of renewable energy sources. In addition, continued demand for fossil fuels means the world will not be able to reduce greenhouse gases in the atmosphere. In this regard, implementing the power plants utilizing the renewable energy sources such as geothermal, solar, biofuel, biomass and so on, is supposed to be of governments' and researchers' interest.

Recent developments in solid oxide fuel cell (SOFC) technology have increased interest in the application toward electricity generation particularly the distributed one. In addition to the advantages of SOFC system over conventional power generation methods, heat from SOFC exhaust can be recovered for combined heat and power (CHP) operations to improve the overall system efficiency.

Undoubtedly, the hydrogen is the genuine fuel for the stack; however, considering its cost and availability, using the natural gas could be more viable, practical and economical in addition to the reforming process of the fuel. Nevertheless, feeding the SOFC with fuels such as biogas, biofuels, syngas and alcohols has become of great interest as they could be suitable alternatives for the natural gas. There are numerous solid waste gasification facilities operating or under construction around the world. Gasification has several advantages over traditional combustion processes for municipal solid waste (MSW) treatment. It takes place in a low oxygen environment that limits the formation of dioxins and of large quantities of SO_x and NO_x . Furthermore, it requires just a fraction of the stoichiometric amount of oxygen necessary for combustion (partial oxidation). As a result, the volume of process gas is low, requiring smaller and less expensive gas cleaning equipment. The lower gas volume also means higher partial

pressure of contaminants in the off-gas, which favors more complete adsorption and particulate capture. Finally, gasification generates a fuel gas that can be integrated with combined cycle turbines, reciprocating engines and, potentially, with fuel cells converting fuel energy to electricity more efficiently than conventional steam boilers[1,2]. Renewability and less CO₂ emission are the greatest advantages of commonly used biomass fuels such as paper, wood, waste straw, saw dust, paddy husk, MSW, etc. [3–6]. Three processes are usually involved in thermochemical conversion of biomass into usable fuels for power plants: combustion, gasification and pyrolysis [7,8]. The gasification process proves to be an efficient technique as it transforms biomass into easily usable fuels to be used for electricity generation [9–11]. There are different types of gasifiers based on the types of moving fluid and solid inside[12]. From the availability view point however, 75% percent of the gasifiers are downdraft, 20% is circulating fluidized bed, 2.5% updraft and 2.5% the other kinds [13].

A 200kW SOFC combined heat and power system has been developed by Omosun et al. [14] to evaluate the system efficiency and its cost analysis. Two different options were investigated; one of them involved cold gas cleaning and the other used hot gas cleaning. The results revealed that system efficiency for the hot process is higher than that for the cold process due to the better heat management in the cleaning process and higher gasification temperature. Despite the capital cost for the hot process is marginally higher, income earned from selling the extra heat produced may justify the additional cost. Singh et al. [15] analyzed the carbon deposition in a solid oxide fuel cell (SOFC) fueled by a biomass. It is reported that carbon deposition decreased to zero as the operating conditions were varied to get a fuel mixture with higher water content (about 15%). The conjunction of biomass gasification with solid oxide fuel cells is investigated by Athanasiou et al. [16] and the results showed that the electrical efficiency of the integrated gasification-

SOFC-steam turbine is about 68% higher than that for the conventional gasification-steam turbine system. A direct internal reforming-SOFC (IR-SOFC) operating with syngas was modeled thermodynamically by Colpan et al [17]. The results showed that recirculation ratio does not have a significant effect for low current density conditions. However, at higher current densities, increasing the recirculation ratio decreases the output power and electrical efficiency of the cell. Jang et al. [18] studied a direct power generation from waste coffee grounds in a biomass fed fuel cell. Results show that biomass type has crucial effect on cell performance. They used waste coffee ground (WCG) as biomass with the benefit of not needing any pre-reformer in the system. It is reported that at cell operating temperature of 900°C the system shows maximum power density twice than that of the carbon black. Pieratti et al. [19] investigated experimentally and theoretically the syngas suitability for solid oxide fuel cell applications. Considering environmental aspects of biomass combustion, steam gasification is used to produce syngas. Experimental data is used to generate and calibrate a 2D theoretical equilibrium model. It is found that the thermodynamic approach is a simple engineering useful tool to obtain reliable results of the gasification model. It is declared that considering the syngas composition and energy content, the obtained syngas is a suitable fuel for fuel cells. Nevertheless, the gas cleaning is still one of the main critical issues. In particular the tar and the H₂S in the gas can rapidly decrease the life of the fuel cells. A new small cogeneration system consisting of a fluidized bed gasifier, coupled to a SOFC and a micro gas turbine is proposed by Di Carlo et al. [20]. Results disclosed that the best case occurs with a temperature of the cathode gas of 800 °C and moisture of 10%, in this case the fuel utilization could be set equal to 0.79 and the electrical efficiency of the overall system is 48%. Focusing on the anode gas recycling, Lorenzo and Fragiaco [21] analyzed the performance of syngas fed SOFC power plant from

the viewpoint of thermodynamics. It is reported that there is an optimum value for anode gas recycle ratio in which the thermal efficiency is maximized. An integrated SOFC and biomass (wood) gasification system using air, enriched air, and steam as gasification agent is investigated by Jia et al. [22]. It is found that when using air or oxygen-enriched air as gasification agent, the gasifier reactor caused the greatest exergy destruction while for steam gasification power systems the largest exergy destruction lies in air heat exchanger. Also, for the efficient CHP case the exergy efficiency is calculated to be 36%. In another work, Jia et al. [23] studied the effects of various parameters such as moisture content in biomass, equivalence ratio and mass flow rate of dry biomass on the overall performance of SOFC based CHP system. It is reported that char in the biomass tends to be converted with decreasing of moisture content and increasing of equivalence ratio due to higher temperature in reduction zone of gasifier. Kartha et al. [24] studied a small-scale biomass fuel cell/gas turbine power systems for rural areas. A downdraft gasifier is used to produce syngas because it is reported to be commercialized and simple in design which has very little amounts of tar (the excessive production of which needs a separate reactor for tar removal and dissipates amounts of flue gas energy) and has simple method of gas cleaning. Also, the efficiency of the studied SOFC-GT was found to be 43.4%. Federico Ghirardo et al. [25] studied heat recovery options for fuel cells. It is found that about 181 kW of heat can be recovered in an ORC to produce 35 kW of electricity. The overall efficiency increases from 44% to 49% when the recovery system is used and the cost of energy drops from 25 c\$/kWh (isolated SOFC system) to 22 c\$/kWh.

Even though continued progress has been made with other alternative treatment technologies (gasification, pyrolysis, plasma, biological drying, etc.), these technologies have by far not seen the same widespread implementation that anaerobic digestion has been able to achieve. In

Europe alone, 244 installations dealing with the organic fraction of municipal solid waste as a significant portion of the feedstock have been constructed or are permitted to be constructed. Feeding SOFCs by biogas is investigated by researchers in the recent years. The performance of biogas-fed solid oxide fuel cell system utilizing different reforming agents (steam, air and combined air/steam) was investigated by Piroonlerkgul et al. [26]. It is observed that for the steam-fed SOFC, there is an optimal amount of steam which provides a maximum power density. However, for the air-fed SOFC system, the power density always decreases with the increase of amount of air due to the dilution effect of nitrogen in air. Three configurations of biogas fed solid oxide fuel cell micro-combined heat and power (micro-CHP) systems are studied with a particular emphasis on the application for single-family detached dwellings by Farhad et al. [27]. Tjaden et al. [28] investigated a small scale biogas-SOFC plant in 2014. Results show that the maximum electrical efficiency is calculated 56.55% which is 15% higher than that of the combustion engines fueled by biogas. Also, the advantages and disadvantages of different reforming process such as steam reforming and auto thermal reforming are reported. The results revealed that the cell design voltage is higher than the cell voltage at which the minimum number of cells is obtained for the SOFC stack. Also, the maximum electrical efficiency of 42.7% is obtained for one of the configurations. Producing biogas from biomass and then feeding either the SOFC or internal combustion engine is studied by Santarelli et al. [29]. Optimization results revealed that produced electrical energy for the SOFC is higher than that for the internal combustion engine where the consumed thermal energy is the same for both systems. Papurello et al. [30] studied the performance of a biogas-fed SOFC power plant experimentally. A 500 W_{el} SOFC stack was installed at a biomass digester pilot plant and was fed with real biogas for more than 400 hours, after which a stable voltage was achieved under

partial oxidation reforming conditions. The fuel utilization was approximately 55% and the electrical efficiency was close to 34%. The biogas which is obtained from organic waste collection from local municipal areas via digester consists of methane and carbon dioxide concentrations ranging from 60-70% and 30-40% vol., respectively. Trendewicz and Braun [31] analyzed a biogas-fueled solid oxide fuel cell (SOFC) system for producing heat and power from the view point of techno-economic. They estimated that the baseline cost of electricity for the small, the medium, and the large plants is 0.079 \$/kWh, 0.058 \$/kWh and 0.05 \$/kWh, respectively. Gandiglio et al. [32] proposed a model to analyze the integration of waste water treatment (WWT) biogas and solid oxide fuel cell considering both the internal and external reforming. The influence of fuel utilization, internal reforming, biogas composition and steam-to-carbon ratio on both the SOFC and overall plant performance is investigated. It is observed that an increase in the methane concentration of biogas would increase the electrical efficiency of the plant slightly. Siefert and Litster [33] investigated the performance of a biogas-fed SOFC from the viewpoint of economics. Their interesting result may be the one revealing that the anaerobic digestion-SOFC system is significantly more economic than the systems in which the biogas is sent to internal combustion engines or micro gas turbines. An exergoeconomic analysis of biogas-fed SOFC power systems focusing on the (anode/cathode) gas recycling investigated by Mehr et al. [34]. It is reported that, the solid oxide fuel cell system with anode and cathode recycling is superior to the other configurations and its efficiency is calculated as 46.09% being 6.81% higher than that of the simple solid oxide fuel cell fed by natural gas. The unit product cost of the solid oxide fuel cell system with anode and cathode gas recycling is calculated as 19.07\$/GJ which is about 35% lower than the corresponding value for the simple natural gas fed solid oxide fuel cell system.

As discussed above, there are two common ways to produce gas from the biomass, using gasifier or digester. In the present work, a downdraft gasifier and a thermophilic digester are used to produce syngas and biogas from the municipal solid waste, respectively. The produced gases are supposed to drive the SOFC system to produce power. As the compositions of biogas and syngas are quite different, and also the exhaust of SOFC is hot enough, the CHP system would be an interesting choice to utilize the hot exhaust of SOFC stack to produce heating. Also, it would be interesting to reveal which system is more efficient and more economical with the almost same working conditions. Modeling of the systems is performed in EES software and the performance of systems is compared with each other from the thermodynamics and thermoeconomics viewpoints.

2. System description and assumptions

2.1 Systems configuration

Schematic diagram of the proposed cogeneration system based on the digester unit system is illustrated in Fig.1a. The system consists of a biogas production unit, a SOFC with anode recycling and heat recovery steam generator (HRSG). Biomass is sent to the digester at environmental conditions and as the digester is considered thermophilic one the temperature of biogas exiting the digester will be higher than environment temperature. Then the biogas is sent to the cleanup unit, in which H_2S is coldly removed and then the clean biogas is sent to the blower. The biogas and air are preheated through the fuel heat exchanger and air heat exchanger, respectively, after being pressurized with the help of fuel and air blowers (the pressure is just to make a flow of fuel and air and compensate the pressure drops within the system). The heated air is sent to the cathode of the stack. On the other hand, the biogas is sent to the anode after mixing

with the recycling of anode stream (state15). The mixed stream experiences the internal reforming process which brings hydrogen-rich products participating in the electrochemical reaction inside the fuel cell stack. An inverter is used to convert the DC power generated by the stack into grid quality electricity. The electrochemical reaction generates thermal energy a part of which is used to deliver the required heat of the internal reforming reaction, another part is employed to heat up the cell products and residual reactants, and the remaining small amount is transferred to the environment as a heat loss (in the present modeling heat loss is neglected). After the finishing of electrochemical reaction in the SOFC stack, the excess air out of the cathode and the unreacted fuel out of the anode combust completely in an after-burner to generate the combustion gas under high temperature. The exhaust gas from the afterburner is sequentially used to preheat the fuel and air, respectively. The exhaust (state 15) is still hot enough to be utilized to produce hot steam. Therefore, a HRSG unit is considered to be coupled with SOFC system. For the maintenance of the digester temperature in the thermophiles condition, the produce hot water can be used to compensate the heat demand of digester. Fig. 1b depicts the use of syngas produced in the gasification process to produce power and heating by means of SOFC power plant and HRSG unit. The description of the process for the system is almost the same as described for the Fig. 1a. The air from environment is brought to the gasifier along with the biomass in the atmospheric pressure. The equilibrium model is presumed in modeling the gasifier. The equilibrium modeling assumes that all the reactions are in thermodynamic equilibrium and that the pyrolysis product (gas) which is product of interest burns and achieves equilibrium in the reduction zone before leaving the downdraft gasifier. Meanwhile, the high temperature syngas produced in gasifier first used to preheat the air before sending it to the mixer to be mixed with anode gas recycle.

2.2 Assumptions

Some meaningful assumptions are considered for the systems modeling as listed below [35,36];

- The atmospheric air is composed of 79% N₂ and 21% O₂, on a volume basis.
- Gasification temperature is assumed to be 1073 K and the syngas is in thermodynamic equilibrium
- A thermophilic digester is used in the modeling
- Fan work in the digester is negligible
- All gases are treated as ideal gases and gas leakage from the components and the connecting pipes is negligible.
- The analysis is carried out under thermodynamic equilibrium and steady state conditions.
- Changes in kinetic and potential energies are neglected.
- Temperatures at channel inlets are the same and, similarly, temperatures at the channel exits are the same.
- The fuel cell is insulated perfectly so that there is no heat interaction with the environment
- Contact resistances are negligible.
- Unreacted gases are assumed to be fully oxidized in the afterburner. [37]

The input data for systems' simulation are listed in Table 1.

3. Energy analysis

3.1 Gasifier modeling

The equilibrium model presumed in gasifier modeling assumes that all the reactions are in thermodynamic equilibrium and that the pyrolysis product burns and achieves equilibrium in the

234 reduction zone before leaving the downdraft gasifier [36]. The reactions in the reduction zone
 235 are as stated in the literature [36,38,39].

236 For a biomass, the global gasification reaction is as follows [40]:

237 The equilibrium constants for methane formation reaction and for the water-gas reaction (shift

$$K_1 = \frac{n_5}{n_1^2} \left(\frac{P/P_{ref}}{n_{tot}} \right)^{-1} \quad (2)$$

$$K_2 = \frac{n_1 n_3}{n_2 n_4} \left(\frac{P/P_{ref}}{n_{tot}} \right)^0 \quad (3)$$

238 reaction) are given by Eqs. 2 and 3, respectively [38]:

239 where n_1 to n_5 are the number of moles in the gasification products in eq. 1. and K_1 and K_2 are
 240 the equilibrium constants which can be related to the change in the Gibbs function as follows
 241 [38]:

$$\frac{-\Delta G_1^0}{\bar{R}T_g} = \ln K_1 \quad (4)$$

242

$$\frac{-\Delta G_2^0}{\bar{R}T_g} = \ln K_2 \quad (5)$$

243 Where $-\Delta G_1^0$ and $-\Delta G_2^0$ are the change in the Gibbs free function of methane formation equation
 244 and shift reaction respectively[36].

245 In Eq. 1, $CH_aO_bN_c$ denotes the biomass, w is the biomass moisture content and m is the kmol of
 246 oxygen per kmol of biomass. The parameter m is actually the air fuel ratio and can be determined
 247 if the gasification temperature is known (or vice versa). The coefficients n_1 to n_6 are determined
 248 through applying the mass balance for H , C , O and N . Based on the ultimate analysis of the
 249 MSW as given in Table 2.

250 The moisture content per mole of biomass can be expressed in terms of mass based moisture
 251 content (MC) as follows [36]:

$$w = \frac{M_{biomass} MC}{18 (1 - MC)} \quad (6)$$

252 where,

253 $MC = (\text{mass of water/mass of wet biomass}) \times 100$

254 Assuming an adiabatic gasification at a temperature of 1073 K, the energy balance equation, as

$$\begin{aligned} \bar{h}_{f-MSW}^0 + w (\bar{h}_{f-H_2O}^0) &= n_1 (\bar{h}_{f-H_2}^0 + \Delta \bar{h}_{H_2}) + n_2 (\bar{h}_{f-CO}^0 + \Delta \bar{h}_{CO}) \\ &+ n_3 (\bar{h}_{f-CO_2}^0 + \Delta \bar{h}_{CO_2}) + n_4 (\bar{h}_{f-H_2O}^0 + \Delta \bar{h}_{H_2O}) + n_5 (\bar{h}_{f-Ch_4}^0 + \Delta \bar{h}_{Ch_4}) + n_6 (\bar{h}_{f-N_2}^0 + \Delta \bar{h}_{N_2}) \end{aligned} \quad (7)$$

255 indicated below, is solved to find the air fuel ratio.

256 In order to validate the gasification model, the experimental and theoretical data reported in

the literature are used for gasification temperature of 1100K and moisture content of 16%. The comparison is shown in Table 3. Referring to Table 3, the sum of hydrogen and carbon monoxide content percentages predicted by the present model is 36.43%, which agrees with the experimental data (35.4%) reported by Jayeh [41]. It is found that the obtained results for the present model agree well with those reported by Jarungthammachote [42] as well.

In order to validate the simulation results of SOFC, the available experimental data reported by Tao et al. [43] is used. Table 4 compares the cell voltage and power density obtained in the present model developed by the authors and those reported by Tao et al. [43]. The comparison shows a good agreement between them.

3.2 Digester modeling

In modeling of digester, a thermophilic anaerobic digester with a temperature of 55°C is used. Note that, it is necessary that temperature fluctuations do not occur in the digester to maintain the microbial activity.

With knowledge of chemical composition of MSW outlined as ultimate analysis in Table 2 the biogas composition can be predicted following the method proposed by Baswell and Hatfield [44]. The global reaction occurring in the digester to produce biogas is:

In the present work, it is assumed that 0.95 of the OFMSW is volatile. A well designed digester aims to destruct at minimum 0.7 of the volatile solid. Following the procedure presented by Murphy[45] the methane and carbon dioxide mass is found. Knowing that the number of molecules in a unit volume under standard conditions is the same for all gases (This volume is 22.412m³/kg) one may find that the 58% of the biogas is methane and 42% of biogas is carbon

278 dioxide in volume.

279 3.3 SOFC with anode recycle model

280 Energy analysis and molar balance for the SOFC with anode and cathode recycle is used in
281 the present work. [46][46]The biogas is converted into a hydrogen-rich synthesis gas inside the
282 fuel cell by making use of internal reforming and shifting reactions [35]. Also syngas (with
283 hydrogen gas) which does not need any reforming and less methane and carbon monoxide gas is
284 reformed inside the SOFC with the same processes as for biogas. The use of an internal reformer
285 also reduces the dependence of the fuel cell on a cooling system. The chemical reactions in the
286 cells are as follows; [47]

287 Equation 9 is reforming reaction and equation 10 is shifting reaction, carbon monoxide in the
288 reforming reaction, reacts with the water which is brought to the SOFC by means of either
289 recycling or external means such as pump, to produce hydrogen. Hydrogen from shifting

290 reaction is used in the electrochemical reaction as below:

291 The molar conversion rates for reforming, shifting and electrochemical reactions are
292 considered to be x_r , y_r , and z_r , respectively. Therefore, rates of consumption and production of
293 the components can be achieved by the following model:

$$x_r \rightarrow [CH_4 + H_2O \rightarrow CO + 3H_2] \quad (\text{Reforming}) \quad (12)$$

$$y_r \rightarrow [CO + H_2O \leftrightarrow CO_2 + H_2] \quad (\text{shifting}) \quad (13)$$

$$z_r \rightarrow \left[H_2 + \frac{1}{2}O_2 \rightarrow H_2O \right] \quad (\text{Overall electrochemical reaction}) \quad (14)$$

294 z_r , could be found with the help of current density, Faraday constant, cell number, and active

$$z_r = \frac{j N_{FC} A_a}{2 F} \quad (15)$$

295 surface area, as followed by equation (16)

296 Applying mass balance equations along with considering equations 13-16 for the mixing units
 297 and the whole SOFC model the flowing gas compositions may be achieved. In order to solve the
 298 system of equations, 3 more equations are needed to complete the system of the equations.
 299 Looking again in the equilibrium reactions of shifting and reforming, the equilibrium constants

$$\ln K_s = -\frac{\Delta \bar{g}_s^o}{\bar{R} T_{FC,e}} = \ln \left[\frac{(\dot{n}_{CO_2,11} + y_r)(\dot{n}_{H_2,11} + 3x_r + y_r - z_r)}{(\dot{n}_{CO,11} + x_r - y_r)(\dot{n}_{H_2O,11} - x_r - y_r + z_r)} \right] \quad (16)$$

$$\ln K_R = -\frac{\Delta \bar{g}_R^o}{\bar{R} T_{FC,e}} = \ln \left[\frac{(\dot{n}_{CO,11} + x_r - y_r)(\dot{n}_{H_2,11} + 3x_r + y_r - z_r)^3 \left(\frac{P_{12}}{P_{ref}} \right)^2}{(\dot{n}_{CH_4,11} + x_r)(\dot{n}_{H_2O,11} - x_r - y_r + z_r) \times \dot{n}_{12}^2} \right] \quad (17)$$

300 can be written as follows respectively:

301 Where, $\bar{R}$ and $T_{FC,e}$ are the **universal gas constant and** the temperature at the exit of the
 302 SOFC, respectively. Also, $\Delta \bar{g}^o$ is the change in the Gibbs free function of shifting and reforming

303 reactions[35].

304 The last equation needed for solving the system equations is obtained using the energy
305 balance for the whole stack. Neglecting the heat loss from the stack, the energy balance can be

$$\dot{W}_{FC,stack} = \sum_k \dot{n}_{k,12} \bar{h}_{k,12} + \sum_L \dot{n}_{L,4} \bar{h}_{L,4} - \sum_m \dot{n}_{m,11} \bar{h}_{m,11} - \sum_n \dot{n}_{n,3} \bar{h}_{n,3} \quad (18)$$

306 written as follows;

307 Where, k , L , m and n are the corresponding gas compositions in each states (e.g. gas
308 composition at state 12 (L) is CO_2 , CO , H_2O , CH_4 , N_2 and H_2). On the other hand, the work rate

$$\dot{W}_{FC,stack} = N_{FC} j A_a V_c \quad (19)$$

309 produced by the SOFC stack $\dot{W}_{FC,stack}$ can be expressed as:

$$V_c = V_N - V_{loss} \quad (20)$$

310 Where cell voltage is defined as:

311 Here, V_N is the Nernst voltage and V_{loss} the voltage loss, which is the sum of three separate
312 voltage losses; Ohmic, Activation and Concentration losses:

$$V_{loss} = V_{ohm} + V_{act} + V_{conc} \quad (21)$$

313 Looking again in the comprehensive analysis of the cell voltage and voltage losses it is found
314 that voltages strongly depend on molar fractions, pressures, electrolyte types and cell operating

temperature that need to be verified very precisely. For the sake of brevity detailed voltage modeling used in the present work has been presented in Appendix A.

3.4 Heat recovery steam generator analysis

One of the determinant parts of the proposed systems is HRSG, which affects the final system specifications and has crucial effect on determining whether to choose gasifier or digester. Gas flow from the AHX is hot enough that can be utilized to generate saturated steam in HRSG. As shown in Fig. 1a and Fig. 1b the HRSG involves economizer (Eco) and evaporator (Eva) parts. Water is pressurized by a pump (P) to meet the required steam pressure for the HRSG.

Applying the energy balance as well as the pinch point temperature difference for the whole HRSG system the mass flow rate of steam and temperature of exhaust can be determined. Energy balance for the economizer and the evaporator parts are as follows:

$$\sum_j n_j \left(\bar{h}_{f_j}^0 + \Delta \bar{h} \right)_{\text{exhaust gas, in}} + n_{\text{water, in}} \bar{h}_{\text{water, in}} = \sum_j n_j \left(\bar{h}_{f_j}^0 + \Delta \bar{h} \right)_{\text{exhaust gas, out}} + n_{\text{water, out}} \bar{h}_{\text{water, out}} \quad (22)$$

Where the amount of heat used for generating hot steam is defined as;

$$\dot{Q}_{\text{Heating}} = \dot{m}_{\text{product gas}} (h_{15} - h_{17}) \quad (23)$$

3.5. First law efficiency for proposed system

Finally with regarding the above mentioned analysis, the first law efficiency for the power generation (electrical efficiency) mode and CHP mode could be defined as follows respectively:

$$\eta_{\text{I,P}} = \frac{\dot{W}_{\text{FC, stack, ac}} - \dot{W}_{\text{FC}} - \dot{W}_{\text{AC}} - \dot{W}_{\text{pump}}}{\dot{m}_{\text{biomass}} \text{LHV}_{\text{biomass}}} \quad (24)$$

$$\eta_{I,CHP} = \frac{\dot{W}_{FC,stack,ac} - \dot{W}_{FC} - \dot{W}_{AC} - \dot{W}_{pump} + \dot{Q}_{Heating}}{\dot{m}_{biomass} LHV_{biomass}} \quad (25)$$

Where $\dot{W}_{FC}$, $\dot{W}_{AC}$ and $\dot{W}_p$ is the amount of fuel compressor power and air compressor power required to blow the fuel and air to the SOFC and pump required power respectively.

4. Exergy analysis

An effective use of energy can be assessed by means of exergy analysis for energy converting systems. Exergy can be divided into four parts: physical, chemical, kinetic and potential exergies. For the processes involved in this paper, the latter two are neglected since the changes in elevation and velocity are negligible [48,49]. Thus, the specific exergy of any stream is expressed as

$$e = e_{ph} + e_{ch} \quad (26)$$

where the physical exergy is defined as [48] :

$$e_{ph,i} = h_i - h_0 - T_0 (s_i - s_0) \quad (27)$$

The specific chemical exergy of a solid biomass fuel can be expressed as follows [36]:

$$e_{biomass}^{ch} = \beta LHV_{biomass} \quad (28)$$

where the factor β in Eq. 28 denotes the ratio of the chemical exergy to the lower heating value (LHV) for the organic fraction of the biomass. A statistical correlation for the β is provided by Szargut and Styrylska [36]:

$$\beta = \frac{1.044 + 0.16 \frac{z_H}{z_c} - 0.34493 \frac{z_o}{z_c} \left(1 + 0.0531 \frac{z_H}{z_c} \right)}{1 - 0.4142 \frac{z_o}{z_c}} \quad (29)$$

343 where z_H, z_c, z_o are the weight fractions of the hydrogen, carbon and oxygen in the biomass,
 344 respectively. The chemical exergy of an ideal gas mixture can be expressed as [48]:

$$e_i^{ch} = \sum_i x_i e_{0,i}^{ch} + \bar{R}T_0 \sum_i x_i \ln x_i \quad (30)$$

345 where x_i is the mole fraction of i_{th} component and $e_{0,i}^{ch}$ is the standard chemical exergy of that
 346 component [38]. The exergy balance for a system component is expressed as:

$$\sum \dot{E}_{in} = \sum \dot{E}_{out} + \dot{E}_D \quad (31)$$

347 With the aid of eq. 31 one may find the exergy destruction in system components in order to
 348 define the most probable candidate of optimizing for higher efficiency.

349 Finally, exergy analysis can be completed by defining the efficiency of second law for the power
 350 generation (electrical efficiency) mode and CHP mode as follows:

$$\eta_{II,P} = \frac{\dot{W}_{FC,stack,ac} - \dot{W}_{FC} - \dot{W}_{AC} - \dot{W}_{pump}}{\dot{E}_{in}} \quad (32)$$

$$\eta_{II,CHP} = \frac{\dot{W}_{FC,stack,ac} - \dot{W}_{FC} - \dot{W}_{AC} - \dot{W}_{pump} + (\dot{E}_{22} - \dot{E}_{20})}{\dot{E}_{in}} \quad (33)$$

351 where $\dot{E}_{in}$ is the rate of input exergy and can be defined as below for gasifier coupled SOFC
 352 and digester coupled SOFC respectively:

$$\dot{E}_{in} = e_{biomass}^{ch} + w e_{water}^{ch} + 4.76 m e_{air}^{ch} + \dot{E}_6 + \dot{E}_{19} \quad (34)$$

$$\dot{E}_{in} = e_{biomass}^{ch} + w e_{water}^{ch} + \dot{E}_{19} \quad (35)$$

5. Economic analysis

5.1. Methodology

It seems that investigating the performance of a system without looking at its product cost will not be accomplished. Integration of economic point of view with thermodynamic seems to be appealing. Exergoeconomic method firstly introduced by Tsatsaronis et al. [50] gets the interest of researchers who use the method to analyze the thermodynamic systems from the viewpoint of economic. The purpose of exergoeconomic analysis for a system is to disclose the cost formation processes and calculate the cost per unit exergy of product streams. To calculate the cost of each unit exergy stream, the cost balance equation along with the required auxiliary equations are applied to each component of the systems. For a system component receiving thermal energy and generating power, the cost balance is written as:

$$\sum \dot{C}_{out,k} + \dot{C}_{w,k} = \sum \dot{C}_{in,k} + \dot{C}_{q,k} + \dot{Z}_{k,PY} \quad (36)$$

$$\dot{C} = c E\dot{x} \quad (37)$$

Where, c is the cost per exergy unit and $E\dot{x}$ is the total exergy rate.

In equation (36), $\dot{Z}_{k,PY}$ is the appropriate charge due to capital investment and operating and maintenance expenses for each component in a reference year. Note that, the cost of the system components which are available in an original year is converted from that original time to a same reference year (year 2013 for present work) with the help of Chemical Engineering Plant Cost Index (CEPEI).

$$\dot{Z}_k^o = \dot{Z}_k^{o,CI} + \dot{Z}_k^{o,OM} \quad (38)$$

370 Cost at reference year=Original cost $\times \frac{\text{Cost index for the reference year}}{\text{Cost index for the original year}}$

371 Or

$$\dot{Z}_{k,PY}^o = \dot{Z}_k^o \frac{CI_{k,PY}}{CI^o} \quad (39)$$

372

373 The term $\dot{Z}_k^o$ in Eq. (38) can be calculated as [48]:

$$\dot{Z}_k^o = \frac{Z_k CRF \varphi}{N} \quad (40)$$

374 Where φ is the maintenance factor, N is the number of system operating hours in a year and

375 CRF is the Capital Recovery Factor, which can be expressed as [51]:

$$CRF = \frac{i_r (1+i_r)^n}{(1+i_r)^n - 1} \quad (41)$$

376 Here, i_r is the interest rate and n is the system life. The input data used in economic

377 evaluations along with the cost and auxiliary equations for each component of the systems is

378 gathered in Table 5.

379 5.2 Cost evaluation

380 To obtain the cost of all unit exergy streams, the linear system of equations is solved

381 assuming that the cost of unit exergies associated with the input fuel is an input.

382 The exergoeconomic evaluation of the systems is carried out using the thermoeconomic

variables, namely, the unit cost of the fuel ($c_{F,k}$), the unit cost of the product ($c_{P,k}$), the cost rate of exergy destruction ($\dot{C}_{D,k}$), the cost rate of exergy loss ($\dot{C}_{L,k}$) and the thermoeconomic factor (f_k). These parameters are calculated using the following relations [48]:

6. Results and discussions

The effect of decision parameters such as the current density, the temperature difference of SOFC stack on efficiencies of power generating system and CHP system along with net power output, heating capacity and unit product cost of the systems is investigated. Nominal values of current density, where maximum power is achieved, are found to be 0.6 mA/cm^2 and 0.2 mA/cm^2 for the D-SOFC and G-SOFC systems respectively.

Fig. 2 shows the effect of current density on the first and second law efficiencies of the power generating system. Referring to Fig. 2, the current density range is lower for G-SOFC system because of N_2 presence in the gasifier exit, which causes partial pressure of components in stack exit to become less than the D-SOFC system and it affects the cell voltage due to decrease in J_{0a} . Looking again in Fig 2, for constant value of fuel utilization factor both first and second law efficiencies tend to decrease with increasing current density. With increasing 0.6 A/cm^2 in current density for the D-SOFC system, first and second law efficiencies tend to decrease by an almost 40%. While the reduction is about 30% for the G-SOFC system (with a possible increase of 0.2 A/cm^2).

Fig. 3a shows the effect of current density on the first and second law efficiencies of the CHP system. The results show that the first law efficiency for the G-SOFC system is in the range of 50%- 74% while the efficiency for the D-SOFC system is obtained in the range of 35%-84%. The great difference between the first and second law efficiency values for G-SOFC system is

due to the exergy rate within the HRSG system (exergy related to heating).

Fig. 3b shows the effect of current density on both the net power output and heating capacity. First important point is that, the net power output is maximized for specific values of current density for both the D-SOFC and G-SOFC systems. The optimum current density value for G-SOFC system is found to be 0.199 A/cm^2 and the corresponding net power output is calculated 46.98 kW . For the D-SOFC system the optimum current density and net power values are 0.64 A/cm^2 and 159.7 kW , respectively. In addition, it is observed that an increase in the current density increases the heating capacity with an almost same trend of power. At the optimum working points (where the net power output is maximized) the heating capacity values are 88.3 kW and 43.31 kW for the G-SOFC and D-SOFC systems, respectively. Another important aspect of Fig 3b is that although the net power output is higher for the digester based system, the heating capacity is higher for the gasifier system which could be interfered from contemplating in Figs 3a and 3b. Also by an increase in current density, the value of heating capacity increases by up to 83% and 45% for the G-SOFC system and D-SOFC system respectively.

Fig. 4 shows the effect of current density on the unit exergy cost of power output (c_w) and hot steam (c_h) for both the D-SOFC and G-SOFC systems. It is revealed that besides the efficiency of D-SOFC is higher it has come at the price of lower unit product cost. Also it is unfolded that for both cases the unit product cost is minimized at some specific point. For the G-SOFC system, the minimum value of unit exergy cost of heating ($24.67 \text{ \$/GJ}$) occurs at current density of 0.203 A/cm^2 while for the case of D-SOFC system the values are $14.17 \text{ \$/GJ}$ and 0.602 A/cm^2 , respectively. It can be seen that even in the minimum values, the D-SOFC system is cost-efficient by 41.6% and 70.2% for heating unit exergy cost and power unit exergy cost, respectively.

Another key parameter having effect on the system performance is the stack temperature difference. Fig. 5 shows the effect of stack temperature difference on second law efficiency of CHP and power generation systems for both the D-SOFC and G-SOFC systems. Second law efficiency for the D-SOFC system is always higher than that for the G-SOFC system but important aspect of this figure is that variation of second law efficiency for power generation mode and CHP mode of G-SOFC tends to decrease after a specific value of temperature. This is actually due to the different composition of inlet gas sent to the anode and consequently different partial pressure of H_2 and H_2O at the anode exit. As the stack temperature difference increases $110^\circ C$, exergetic efficiency for D-SOFC system (in the CHP mode) rises by 52.9% while with an increase of $90^\circ C$ the efficiency of the G-SOFC system increases by 75.3%. In addition, as the temperature difference increases by $80^\circ C$ the second law efficiency of power generation system for the G-SOFC system rises by 25%, the change is almost the same for the case of D-SOFC with a value of 25.4%.

Fig. 6a shows the effect of stack temperature difference on the net power output and heating capacity for the D-SOFC and G-SOFC systems. Comparing the G-SOFC and D-SOFC systems, net power output of G-SOFC system increases by 27.60% with an increase in stack temperature difference and for the D-SOFC system the increase is 25.5%. The trend of heat duty is different as with an increase in temperature of stack results in an increase of exhaust potential of SOFC system which would be utilized in HRSG system. Although the trend seems to be similar for two cases, for the D-SOFC system the percentage of increase is much higher compared to the G-SOFC system.

Fig. 6b shows the effect of stack temperature difference on unit exergy costs of heating capacity and power output for both the D-SOFC and G-SOFC systems. It is revealed that for the

D-SOFC system unit heating product cost is minimized at stack temperature difference of 183 K which corresponds to unit cost of 9.18 \$/GJ while the stack temperature difference and unit cost values are 135.6 K and 16.1 \$/GJ for the G-SOFC system. Also, at the minimum point the D-SOFC system has 75.3% less unit product cost in heating and 91.31% in power unit product cost compared to the G-SOFC system.

Finally to give an insight of overall product cost variation with terminal temperature differences of SOFC stack Fig. 6c is presented. It shows that the with a change of about 100 °C in stack temperature difference, the minimum unit product cost of G-SOFC system is more than the maximum unit product cost of D-SOFC system.

Fig. 7a and Fig. 7b illustrate the G-SOFC and D-SOFC systems' calculated parameters at nominal operating condition and stack temperature difference equal to 100 °C. According to Fig. 7a the second law efficiency for the D-SOFC system is higher with a value of 97.8% in power generation system and 57.7% in CHP system. The difference becomes less in CHP system due to higher heating capacity in G-SOFC system, moreover considering the results illustrated in Fig. 7b it is found that the unit product cost for G-SOFC system for power generation system and CHP system is 42.6% and 24.5% more than those for the D-SOFC system respectively. Fig. 7b shows the value of net output power and heating capacity as well as the unit product cost for power and heating for the two proposed systems at the same working conditions. Fig.7b shows that the G-SOFC system has 111 kW less power output and 45.9kW more heating load than the D-SOFC system.

One method to illustrate exergy accounting graphically is the Grassman diagram [48]. The width of the arrows entering or leaving the control volume is a quantitative measure of designated parameter. Also for the sake of brevity, values of exergy destruction along with

entering and leaving exergy to the whole system are presented in Table 6. According to the Figs. 8a and 8b and Table 6, one may conclude that the air heat exchanger and the gasifier are the main sources of irreversibility due to the existence of three sources of irreversibility (temperature difference, chemical reaction along with system friction) within these components in the D-SOFC and G-SOFC systems respectively.

Table 7 and Table 8 show the exergoeconomic analysis results for the G-SOFC and D-SOFC systems. Last column of these tables is exergoeconomic factor which a low value of this factor calculated for a major component suggests that cost saving in the entire system *might* be achieved by improving the component efficiency (reducing exergy destruction) even if the capital investment for the component will increase. However, the exergoeconomic factor is not sufficient to explain if a component has to be modified or not. As an example: even if a component has a too low value of exergoeconomic factor (suggesting therefore its substitution with a component of higher performance and higher cost) if the same component elaborates a quantity of fuel which is negligible (and so it has a low value of the so called exergetic factor) it is not worth at all to substitute this component with a better one, as its “exergy role” on the system is simply negligible. The most important components to discuss are the components elaborating a large amount of inlet fuel (so, which have a high value of exergetic factor): only in their case it is interesting to analyze the values of their exergoeconomic factor. Referring to first column of Tables 7 and 8, it can be noted that for the gasifier based system, among the components having higher inlet exergy (SOFC stack, gasifier, after burner and AHX respectively) the SOFC stack and AHX have the highest (88.75%) and lowest (16.02%) exergoeconomic factors, respectively. Therefore, for the case of G-SOFC system, on the one hand, engineers should focus on reducing the investment and operation costs of SOFC stack and on the other

hand, they are to reduce the costs associated with exergy destruction for the AHX. The same point can be stated for the case of D-SOFC. Therefore, for the D-SOFC and G-SOFC systems, not only designers should emphasize on decreasing the investment cost of SOFC stack but also reducing the cost associated with exergy destruction within the air heat exchangers should be in priority.

Finally at the end, a summary of plant type, fuel type and technology of using biomass to produce gas to feed SOFC power plant in some published works as well as those proposed and obtained in the present work are listed in Table 9. Comparison shows that most of the published works focused on just one technology (gasification to produce syngas or digestion to produce biogas) to utilize the biomass. Also there are few works that comprehensively analyzed the system from the both of thermodynamic and techno economic point of view. However, in the present work, the investigation has been made to fulfill this gap and the thermodynamic and economic analyses are performed to compare two well-known technologies of using biomass in the SOFC system.

7. Conclusion

A comprehensive thermodynamic and thermoeconomic modeling are performed for two proposed cogeneration systems based on SOFC system fed by municipal solid waste. The inlet fuel for the SOFC is a type of syngas produced by gasification process of municipal solid waste or a biogas produced by digestion process. For the comparison purposes, the systems analyzed in two modes; one-generation system (produce power) and a CHP mode (producing power and heating simultaneously). Parametric studies revealed that stack temperature difference along with current density has crucial effect on systems' performance. Additional conclusions are as

follows:

- D-SOFC system has higher efficiency from the viewpoints of energy and exergy when the systems run to produce power.
- D-SOFC system has higher second law efficiency in CHP mode; however the first law efficiency for the G-SOFC is higher in this mode.
- D-SOFC system has more power output but less heating capacity compared to those of the G-SOFC system.
- For the case of G-SOFC system the gasifier is the main source of irreversibility due to temperature difference and chemical reaction. Meanwhile, air heat exchanger is the second source of irreversibility because of large temperature difference on the both sides of heat exchanger. For the D-SOFC system, air heat exchanger has the most distribution in exergy destruction within the system, the stack and digester are the second and third respectively.

Appendix A

Here, the electrochemical model (for calculating the cell voltage) programing in EES is given in details. The cell voltage can be defined as;

$$V_c = V_N - V_{loss} \quad A$$

1

538 where, V_N is the Nernst voltage and V_{loss} is the voltage loss which is the sum of three

$$V_{loss} = V_{ohm} + V_{act} + V_{conc} \quad A$$

2

539 separate voltage losses (ohmic, activation, and concentration losses):

$$V_N = -\frac{\Delta \bar{g}^o}{2F} + \frac{\bar{R}T_{FC}}{2F} \ln \left(\frac{a_{H_2}^{Anode, exit} \sqrt{a_{O_2}^{Cathode, exit}}}{a_{H_2O}^{Anode, exit}} \right) \quad A3$$

540 The Nernst voltage which is accounted as the ideal voltage can be expressed as;

541 In equation (A3), the Gibbs energy difference is related to the overall electrochemical
542 reaction. To determine the actual cell voltage, the voltage losses should be calculated. To
543 calculate the Ohmic loss the following formula is used [52];

$$V_{ohm} = (R_{Int} + \rho_{an} L_{an} + \rho_{cat} L_{cat} + \rho_{ely} L_{ely}) j \quad A4$$

544 where, ρ , L and R_{Int} denote electrical resistivity of a cell component, thickness of a cell
545 component and interconnection resistivity, respectively (See Table A.1).

546 The activation polarization is the sum of those defined for both the anode and cathode as
547 follows;

$$V_{act} = V_{act,a} + V_{act,c} \quad A5$$

$$V_{act,c} = \frac{\bar{R}T}{F} (\sinh^{-1}(\frac{j}{2j_{0a}})) \quad A6$$

$$V_{act,c} = \frac{\bar{R}T}{F} (\sinh^{-1}(\frac{j}{2j_{0c}})) \quad A7$$

548 Where j_0 is the exchange current density. Eqs. (A8) and (A9) are used to evaluate the values
549 of the exchange current density for the anode and the cathode, (see variables in Table A.2),

$$j_{0,a} = \gamma_{an} \left(\frac{RT}{2F} \right) e^{\left(-\frac{E_{a,an}}{\bar{R}T} \right)} \quad A8$$

$$j_{0,c} = \gamma_{cat} \left(\frac{RT}{2F} \right) e^{\left(-\frac{E_{a,cat}}{\bar{R}T} \right)} \quad A9$$

550 respectively [52].

551 Concentration loss is sum of the losses related to gas concentration occurring in the anode

$$V_{conc} = V_{conc,a} + V_{conc,c} \quad A10$$

552 and cathode.

$$V_{conc,a} = \frac{RT}{2F} \ln \left(\frac{P_{H_2} P_{H_2O,TPB}}{P_{H_2O} P_{H_2,TPB}} \right) \quad A11$$

553 Where

$$V_{conc,cat} = \frac{RT}{4F} \log \left(\frac{P_{O_2}}{P_{O_2,TPB}} \right) \quad A12$$

554 And

555 where the subscript *TPB* denotes the three-phase boundary. To calculate the pressure at the

$$P_{H_2O,TPB} = P_{H_2O,an} + j \frac{R T L_{an}}{2 F D_{an,H_2}^{eff}} \quad A13$$

556 reaction sites, the following equations have been used [52,53]:

$$P_{H_2,TPB} = P_{H_2,an} - j \frac{R T L_{an}}{2 F D_{an,H_2O}^{eff}} \quad A14$$

$$P_{O_2,TPB} = P_{cat} - (P_{cat} - P_{O_2,cat}) \exp(j \frac{R T L_{cat}}{4 F D_{O_2}^{eff} p_{cat}}) \quad A15$$

557

558 where, $D_{H_2}^{eff}$, $D_{H_2O}^{eff}$ and $D_{O_2}^{eff}$ are the effective gaseous diffusivity through the anode (for H₂),

559 anode (for H₂O) and the cathode (for O₂), respectively. The effective gaseous diffusivity can be

$$\frac{1}{D_{an,H_2}^{eff}} = \frac{\varepsilon_{an}}{\tau_{an}} \left(\frac{1}{D_{H_2,K}} + \frac{1}{D_{H_2,H_2O}} \right) \quad A16$$

$$\frac{1}{D_{an,H_2O}^{eff}} = \frac{\varepsilon_{an}}{\tau_{an}} \left(\frac{1}{D_{H_2O,K}} + \frac{1}{D_{H_2O,H_2}} \right) \quad A17$$

$$\frac{1}{D_{cat,O_2}^{eff}} = \frac{\varepsilon_{cat}}{\tau_{cat}} \left(\frac{1}{D_{O_2,K}} + \frac{1}{D_{O_2,N_2}} \right) \quad A18$$

560 calculated as [52,53];

561 Where the porosity (ε) and tortuosity (τ) of electrode materials are estimated to be 0.48 and

562 5.4, respectively. To calculate the effective gaseous diffusivity, combined ordinary and Knudsen

563 diffusion should be defined and calculated using the following equations as[52];

$$D_{H_2,K} = 97 r_{pore,an} \sqrt{\frac{T}{M_{H_2}}} \quad A19$$

$$D_{H_2O,K} = 97 r_{pore,an} \sqrt{\frac{T}{M_{H_2O}}} \quad A20$$

$$D_{O_2,K} = 97 r_{pore,cat} \sqrt{\frac{T}{M_{O_2}}} \quad A21$$

$$D_{H_2,H_2O} = \frac{1.43 \times 10^{-7} T^{1.75}}{\sqrt{M_{H_2,H_2O}} (V_{H_2}^{1/3} + V_{H_2O}^{1/3})^2 P} \quad A22$$

$$D_{O_2,N_2} = \frac{1.43 \times 10^{-7} T^{1.75}}{\sqrt{M_{O_2,N_2}} (V_{O_2}^{1/3} + V_{N_2}^{1/3})^2 P} \quad A$$

23

564

565 Where M is molecular weight of species, V represents diffusion volume of species. Meanwhile,
 566 pore radius value (r_{pore}) is estimated to be $0.5 \mu m$.

567

568

569

570

571

572

573

574

575

576 **References**

577

578 [1] Basu P. Combustion and gasification in fluidized beds. Broken Sound Parkway NW, Suit
579 300: CRC press (Taylor and Francis); 2006.

580

581 [2] Basu P. Biomass gasification, pyrolysis and torrefaction: practical design and theory. 2nd
582 ed. 32 Jamestown Road, London NW1 7BY, UK: Academic press (Elsevier); 2013.

583

584 [3] Mckendry P. Energy production from biomass (part 3): gasification technologies.
585 Bioresour Technol 2002;83:55–63.

586

587 [4] Mckendry P. Energy production from biomass (part 1): overview of biomass. Bioresour
588 Technol 2002;83:37–46.

589

590 [5] Mckendry P. Energy production from biomass (part 2): conversion technologies.
591 Bioresour Technol 2002;83:47–54.

592

593 [6] Soltani S, Yari M, Mahmoudi SMS, Morosuk T, Rosen MA. Advanced exergy analysis
594 applied to an externally-fired combined-cycle power plant integrated with a biomass
595 gasification unit. Energy 2013;59:775–80.

596

597 [7] Saidur R, Abdelaziz EA, Demirbas A, Hossain MS, Mekhilef S. A review on biomass as a
598 fuel for boilers. Renew Sustain Energy Rev 2011;15:2262–89.

599

600 [8] Yoshioka T, Hirata S, Matsumura Y, Sakanishi K. Woody biomass resources and
601 conversion in Japan: The current situation and projections to 2010 and 2050. Biomass and
602 Bioenergy 2005;29:336–46.

603

604 [9] Sebastián F, Royo J, Gómez M. Cofiring versus biomass-fired power plants: GHG
605 (Greenhouse Gases) emissions savings comparison by means of LCA (Life Cycle
606 Assessment) methodology. Energy 2011;36:2029–37.

607

608 [10] Karamarkovic R, Karamarkovic V. Energy and exergy analysis of biomass gasification at
609 different temperatures. Energy 2010;35:537–49.

610

611 [11] Soltani S, Mahmoudi SMS, Yari M, Rosen MA. Thermodynamic analyses of a biomass
612 integrated fired combined cycle. Appl Therm Eng 2013;59:60–8.

613

614 [12] Warnecke R. Gasification of biomass: comparison of fixed bed and fluidized bed gasifier.

Biomass and Bioenergy 2000;18:489–97.

- [13] Knoef HAM. Inventory of biomass gasifier manufacturers and installations. Final Report to European Commission. Contract DIS/1734/98-NL, Biomass Technol Gr BV, Univ Twente, Enschede 2000.
- [14] Omosun AO, Bauen A, Brandon NP, Adjiman CS, Hart D. Modelling system efficiencies and costs of two biomass-fuelled SOFC systems. *J Power Sources* 2004;131:96–106.
- [15] Singh D, Hernández-Pacheco E, Hutton PN, Patel N, Mann MD. Carbon deposition in an SOFC fueled by tar-laden biomass gas: A thermodynamic analysis. *J Power Sources* 2005;142:194–9.
- [16] Athanasiou C, Coutelieris F, Vakouftsi E, Skoulou V, Antonakou E, Marnellos G, et al. From biomass to electricity through integrated gasification/SOFC system-optimization and energy balance. *Int J Hydrogen Energy* 2007;32:337–42.
- [17] Colpan CO, Dincer I, Hamdullahpur F. Thermodynamic modeling of direct internal reforming solid oxide fuel cells operating with syngas. *Int J Hydrogen Energy* 2007;32:787–95.
- [18] Jang H, Ocon JD, Lee S, Lee JK, Lee J. Direct power generation from waste coffee grounds in a biomass fuel cell. *J Power Sources* 2015;296:433–9.
- [19] Pieratti E, Baratieri M, Ceschini S, Tognana L, Baggio P. Syngas suitability for solid oxide fuel cells applications produced via biomass steam gasification process: Experimental and modeling analysis. *J Power Sources* 2011;196:10038–49.
- [20] Di Carlo A, Bocci E, Naso V. Process simulation of a SOFC and double bubbling fluidized bed gasifier power plant. *Int J Hydrogen Energy* 2013;38:532–42.
- [21] De Lorenzo G, Fragiaco P. Energy analysis of an SOFC system fed by syngas. *Energy Convers Manag* 2015;93:175–86.
- [22] Jia J, Abudula A, Wei L, Sun B, Shi Y. Thermodynamic modeling of an integrated biomass gasification and solid oxide fuel cell system. *Renew Energy* 2015;81:400–10.
- [23] Jia J, Abudula A, Wei L, Sun B, Shi Y. Effect of operating parameters on performance of an integrated biomass gasifier, solid oxide fuel cells and micro gas turbine system.

Biomass and Bioenergy 2015;75:35–45.

- [24] Kartha S, Kreutz TG, Williams RH. Small-scale biomass fuel cell/gas turbine power systems for rural areas. *Energy Sustain Dev* 2000;4:85–9.
- [25] Ghirardo F, Santin M, Traverso A, Massardo A. Heat recovery options for onboard fuel cell systems. *Int J Hydrogen Energy* 2011;36:8134–42.
- [26] Piroonlerkgul P, Assabumrungrat S, Laosiripojana N, Adesina AA. Selection of appropriate fuel processor for biogas-fuelled SOFC system. *Chem Eng J* 2008;140:341–51.
- [27] Farhad S, Hamdullahpur F, Yoo Y. Performance evaluation of different configurations of biogas-fuelled SOFC micro-CHP systems for residential applications. *Int J Hydrogen Energy* 2010;35:3758–68.
- [28] Tjaden B, Gandiglio M, Lanzini A, Santarelli M, Järvinen M. Small-Scale Biogas-SOFC Plant: Technical Analysis and Assessment of Different Fuel Reforming Options. *Energy & Fuels* 2014;28:4216–32.
- [29] Santarelli M, Barra S, Sagnelli F, Zitella P. Biomass-to-electricity: Analysis and optimization of the complete pathway steam explosion - enzymatic hydrolysis - anaerobic digestion with ICE vs SOFC as biogas users. *Bioresour Technol* 2012;123:430–8.
- [30] Papurello D, Lanzini A, Tognana L, Silvestri S, Santarelli M. Waste to energy: Exploitation of biogas from organic waste in a 500 W solid oxide fuel cell (SOFC) stack. *Energy* 2015;85:145–58.
- [31] Trendewicz a. a., Braun RJ. Techno-economic analysis of solid oxide fuel cell-based combined heat and power systems for biogas utilization at wastewater treatment facilities. *J Power Sources* 2013;233:380–93.
- [32] Gandiglio M, Lanzini A, Santarelli M, Leone P. Design and Balance-of-Plant of a Demonstration Plant With a Solid Oxide Fuel Cell Fed by Biogas From Waste-Water and Exhaust Carbon Recycling for Algae Growth. *J Fuel Cell Sci Technol* 2014;11:031003.
- [33] Siefert NS, Litster S. Exergy & economic analysis of biogas fueled solid oxide fuel cell systems. *J Power Sources* 2014;272:386–97.

- [34] Mehr AS, Mahmoudi SMS, Yari M, Chitsaz A. Thermodynamic and exergoeconomic analysis of biogas fed solid oxide fuel cell power plants emphasizing on anode and cathode recycling: A comparative study. *Energy Convers Manag* 2015;105:596–606.
- [35] Ranjbar F, Chitsaz A, Mahmoudi SMS, Khalilarya S, Rosen MA. Energy and exergy assessments of a novel trigeneration system based on a solid oxide fuel cell. *Energy Convers Manag* 2014;87:318–27.
- [36] Soltani S, Mahmoudi SMS, Yari M, Rosen MA. Thermodynamic analyses of an externally fired gas turbine combined cycle integrated with a biomass gasification plant. *Energy Convers Manag* 2013;70:107–15.
- [37] Al-Sulaiman FA, Dincer I, Hamdullahpur F. Energy analysis of a trigeneration plant based on solid oxide fuel cell and organic Rankine cycle. *Int J Hydrogen Energy* 2010;35:5104–13.
- [38] Landau L, Moran MJ, Shapiro HN, Boettner DD, Bailey M. *Fundamentals of engineering thermodynamics*. John Wiley & Sons; 2010.
- [39] Gholamian E, Mahmoudi SMS, Zare V. Proposal, exergy analysis and optimization of a new biomass-based cogeneration system. *Appl Therm Eng* 2016;93:223–35.
- [40] Zainal ZA, Ali R, Lean CH, Seetharamu KN. Prediction of performance of a downdraft gasifier using equilibrium modeling for different biomass materials. *Energy Convers Manag* 2001;42:1499–515.
- [41] Jayah TH, Aye L, Fuller RJ, Stewart DF. Computer simulation of a downdraft wood gasifier for tea drying. *Biomass and Bioenergy* 2003;25:459–69.
- [42] Jarunghammachote S, Dutta A. Thermodynamic equilibrium model and second law analysis of a downdraft waste gasifier. *Energy* 2007;32:1660–9.
- [43] Tao G, Armstrong T, Virkar A. Intermediate temperature solid oxide fuel cell (IT-SOFC) research and development activities at MSRI. *Ninet. Annu. ACERC&ICES Conf. Utah*, 2005.
- [44] Buswell AM, Hatfield WD. Anaerobic fermentations. *Bull* 1936;32.
- [45] Wellinger A, Murphy JD, Baxter D. *The biogas handbook: science, production and*

applications. Elsevier; 2013.

- [46] Ryu C, Yang Y Bin, Khor A, Yates NE, Sharifi VN, Swithenbank J. Effect of fuel properties on biomass combustion: Part I. Experiments-fuel type, equivalence ratio and particle size. *Fuel* 2006;85:1039–46.
- [47] Chan SH, Ho HK, Tian Y. Modelling of simple hybrid solid oxide fuel cell and gas turbine power plant. *J Power Sources* 2002;109:111–20.
- [48] Bejan A, Moran MJ. Thermal design and optimization. John Wiley & Sons; 1996.
- [49] Ahmadi P, Dincer I, Rosen MA. Development and assessment of an integrated biomass-based multi-generation energy system. *Energy* 2013;56:155–66.
- [50] Tsatsaronis G, Lin L, Pisa J. Exergy costing in exergoeconomics. *J Energy Resour Technol* 1993;115:9–16.
- [51] Mehr AS, Zare V, Mahmoudi SMS. Standard GAX versus hybrid GAX absorption refrigeration cycle: From the view point of thermoeconomics. *Energy Convers Manag* 2013;76:68–82.
- [52] Wongchanapai S, Iwai H, Saito M, Yoshida H. Selection of suitable operating conditions for planar anode-supported direct-internal-reforming solid-oxide fuel cell. *J Power Sources* 2012;204:14–24.
- [53] Lanzini A, Santarelli M, Orsello G. Residential solid oxide fuel cell generator fuelled by ethanol: Cell, stack and system modelling with a preliminary experiment. *Fuel Cells* 2010;10:654–75.
- [54] Madi H, Lanzini A, Diethelm S, Papurello D, Van herle J, Lualdi M, et al. Solid oxide fuel cell anode degradation by the effect of siloxanes. *J Power Sources* 2015;279:460–71. doi:10.1016/j.jpowsour.2015.01.053.
- [55] Al-Sulaiman FA, Dincer I, Hamdullahpur F. Energy and exergy analyses of a biomass trigeneration system using an organic Rankine cycle. *Energy* 2012;45:975–85.
- [56] Farhad S, Yoo Y, Hamdullahpur F. Effects of fuel processing methods on industrial scale biogas-fuelled solid oxide fuel cell system for operating in wastewater treatment plants 2010;195:1446–53.

- [57] Bang-Møller C, Rokni M, Elmegaard B. Exergy analysis and optimization of a biomass gasification, solid oxide fuel cell and micro gas turbine hybrid system. *Energy* 2011;36:4740–52.
- [58] El-Emam RS, Dincer I, Naterer GF. Energy and exergy analyses of an integrated SOFC and coal gasification system. *Int J Hydrogen Energy* 2012;37:1689–97.
- [59] Wongchanapai S, Iwai H, Saito M, Yoshida H. Performance evaluation of an integrated small-scale SOFC-biomass gasification power generation system. *J Power Sources* 2012;216:314–22.
- [60] Campitelli G, Cordiner S, Gautam M, Mariani A, Mulone V. Biomass fueling of a SOFC by integrated gasifier: Study of the effect of operating conditions on system performance. *Int J Hydrogen Energy* 2013;38:320–7.
- [61] Arteaga-Pérez LE, Casas-Ledón Y, Pérez-Bermúdez R, Peralta LM, Dewulf J, Prins W. Energy and exergy analysis of a sugar cane bagasse gasifier integrated to a solid oxide fuel cell based on a quasi-equilibrium approach. *Chem Eng J* 2013;228:1121–32.
- [62] Morandin M, Maréchal F, Giacomini S. Synthesis and thermo-economic design optimization of wood-gasifier-SOFC systems for small scale applications. *Biomass and Bioenergy* 2013;49:299–314.
- [63] Ozcan H, Dincer I. Performance evaluation of an SOFC based trigeneration system using various gaseous fuels from biomass gasification. *Int J Hydrogen Energy* 2014:1–10.
- [64] Caliandro P, Tock L, Ensinas A V., Marechal F. Thermo-economic optimization of a Solid Oxide Fuel Cell - Gas turbine system fuelled with gasified lignocellulosic biomass. *Energy Convers Manag* 2014;85:764–73.
- [65] Curletti F, Gandiglio M, Lanzini A, Santarelli M. Large size biogas-fed Solid Oxide Fuel Cell power plants with carbon dioxide management: Technical and economic optimization 2015;294.
- [66] Lv X, Liu X, Gu C, Weng Y. Determination of safe operation zone for an intermediate-temperature solid oxide fuel cell and gas turbine hybrid system. *Energy* 2016;99:91–102.

809

810 **Figures' caption**

811

812 Figure 1 schematic diagram of CHP system based on a) digester coupled SOFC, b) gasifier coupled
813 SOFC

814 Figure 2 Effect of current density on first and second law efficiencies of power generating system

815 Figure 3 Effect of current density on a) first and second law efficiencies of CHP system b) net power
816 output and heating value of CHP system

817 Figure 4 effect of current density unit product cost of heat and power

818 Figure 5 Effect of stack temperature difference on second law efficiency of power generating and CHP
819 system

820 Figure 6 effect of stack temperature difference on a) net power output and heating capacity b) unit
821 product cost of heating and power c) total product cost of digester coupled SOFC and gasifier coupled
822 SOFC

823 Figure 7 Comparison of a) first and second law efficiencies of systems as well as the total product cost
824 b) net output power and heating load of systems as well as the their product costs

825 Figure 8 Grassman diagram of the a) digester coupled CHP system based on SOFC (D-SOFC) b)
826 gasifier coupled CHP system based on SOFC (G-SOFC)

827

828

829

830

831

832

833

834

835 **Tables' Caption**

836 Table 1. Input data for the SOFC systems [34,37,45,55]

837 Table 2 Ultimate analysis of MSW [39]

838 Table 2. The comparison of the component percentages in the producer gas obtained from the gasification
839 in the present work and those reported in the literature, for wood with a moisture content of 16% and for a
840 gasification temperature of 1100K.

841 Table 3. Comparison of results obtained from the present work with the experimental values reported by
842 Tao et al. [43]

843 Table 4 Input data* and cost and auxiliary equations for each component [11,33]

844 Table 6. Exergy and exergy destruction rates for two proposed SOFC systems

845 Table 7 Exergoeconomic analysis results for the gasifier coupled SOFC

846 Table 8 Exergoeconomic analysis results for the Digester coupled SOFC

847 Table A.1. Material Resistivity used for ohmic voltage loss estimation [52]

848 Table A.2. Parameters correspond to anode and cathode sides material [52]

849

850

851

852

853

854

855

856

857

858

[illegible][illegible]

42

Figure 2 Effect of current density on first and second law efficiencies of power generating system

a)

Figure 3 Effect of current density on a) first and second law efficiencies of CHP system b) net power output and heating value of CHP system

872
873
874
875
876
877
878
879
880
881
882
883
884

Figure 4 effect of current density unit product cost of heat and power

Figure 5 Effect of stack temperature difference on second law efficiency of power generating and CHP system

a)

Figure 6 effect of stack temperature difference on a) net power output and heating capacity b) unit product cost of heating and power c) total product cost of digester coupled SOFC and gasifier coupled SOFC

a)

b)

Figure 7 Comparison of a) first and second law efficiencies of systems as well as the total product cost b) net output power and heating load of systems as well as the their product costs

a)

b)

Figure 8 Grassman diagram of the a) digester coupled CHP system based on SOFC (D-SOFC) b) gasifier coupled CHP system based on SOFC (G-SOFC)

900

901

902

903 **Tables**

Table 1. Input data for the SOFC systems [34,37,45,55]

SOFC system			Unit
	Temperature difference between stack inlet and outlet	100	K
	Fuel utilization factor for whole SOFC	0.80	-
	Active surface area	50	cm²
	DC-AC inverter efficiency	97	%
	Base inlet temperature to SOFC	973.15	K
	Steam to carbon ratio	2	-
	Thickness of anode	500	μm
	Thickness of cathode	50	μm
	Thickness of electrolyte	10	μm
	Fuel blower isentropic efficiency	80	%
	Air blower isentropic efficiency	80	%
	Pump isentropic efficiency	80	%
	Number of cells	11,000	-
	Afterburner combustion efficiency	99	%
	Stack pressure drop	2	%
	Heat exchangers pressure drop	3	%
	Afterburner pressure drop	5	%
Digester			
	Work needed to drive the fan	0	kW
	Exit temperature (Thermophilic digester)	328	K
	Amount of volatile solid	95	%
	Amount of destruction in digester	70	%
Gasifier			
	Gasification temperature	1073.15	K
	Heat loss from gasifier	0	%
	Air inlet temperature	298	K
	Biomass inlet temperature	298	K
HRSG			
	Pinch point temperature difference	15	K
	Steam pressure	10	bar
	Water pump isentropic efficiency	0.75	-

904

905

906

Table 2 Ultimate analysis of MSW [39]

Biomass	C	H	N	S	O	Ash	Higher heating value (kJ/kmol)
Municipal solid waste	47.6	6	1.2	0.3	32.9	12	433034

Table 3. The comparison of the component percentages in the producer gas obtained from the gasification in the present work and those reported in the literature, for wood with a moisture content of 16% and for a gasification temperature of 1100K.

Constituent	Present model	Experiment [40]	Jarunghammachote equilibrium model [42]
Hydrogen	17.15	15.5	18.04
Carbon monoxide	19.28	19.1	17.86
Methane	0.55	1.1	0.11
Carbon dioxide	10.81	11.4	11.84
Nitrogen	52.21	52.9	52.15

Table 4. Comparison of results obtained from the present work with the experimental values reported by Tao et al. [43]

Current density (A/m ²)	Cell voltage (V) (Present work)	Cell voltage (V) (Tao et al.)	Error (%)	Power density (W/m ²) (Present work)	Power density (W/m ²) (Tao et al.)	Error (%)
2000	0.742	0.76	-2.368	0.148	0.15	-1.333
3000	0.684	0.68	0.588	0.205	0.21	-2.381
4000	0.634	0.62	2.258	0.253	0.26	-2.692
5000	0.582	0.57	2.105	0.294	0.295	-0.339
6000	0.547	0.52	5.192	0.328	0.315	4.127

Table 5 Input data* and cost and auxiliary equations for each component [11,33]

Auxiliary equations	Cost equations	Component
$c_{biomass}=2$	$Z_{gasifier}=1600 \left(\dot{m}_{drybiomass} \right)^{0.67}$	Gasifier
$c_{biomass}=2$	$Z_{Digester}=350000 \left(\frac{\dot{V}_T}{21000} \right)^{0.75}$	Digester
$\dot{C}_{14}/\dot{E}_{14}=\dot{C}_{33}/\dot{E}_{33}$ $\dot{C}_5/\dot{E}_5=\dot{C}_{33}/\dot{E}_{33}$	$Z_{SOFC}=A_a N_{FC} (2.96 T_{FC,e} - 1907)$	SOFC stack
-	$Z_{AB}=\frac{46.08\dot{m}_7}{(0.955-(P_{17}/P_7))} \left(1+e^{(0.018T_{17}-26.4)} \right)$	Afterburner
$c_1=0$	$Z_{AC}=91562 \left(\dot{W}_{AC}/455 \right)^{0.67}$	Air compressor
$c_{10}=c_F$	$Z_{FC}=91562 \left(\dot{W}_{FC}/455 \right)^{0.67}$	Fuel compressor
$c_{20}=0$	$Z_{P1}=1785 f_n \left(\dot{W}_P/1 \right)^{0.71}$ $f_n=1+(0.2/(1-\eta_P))$	Pump
$\dot{C}_{17}/\dot{E}_{17}=\dot{C}_{18}/\dot{E}_{18}$	$Z_{FHX}=130 (A_{FHX}/0.093)^{0.78}$	FHX
$\dot{C}_{18}/\dot{E}_{18}=\dot{C}_{19}/\dot{E}_{19}$	$Z_{AHX}=390 (A_{AHX}/0.093)^{0.78}$	AHX
$\dot{C}_{19}/\dot{E}_{19}=\dot{C}_{20}/\dot{E}_{20}$	$Z_{HRSG}=6570 \left(\left(\dot{Q}_{eco}/\Delta T_{eco} \right)^{0.8} + \left(\dot{Q}_{eva}/\Delta T_{eva} \right)^{0.8} \right) +$ $21276 \dot{m}_{steam} + 1184.4 \left(\dot{m}_{gas} \right)^{1.2}$	HRSG
-	$Z_{inv}=100000 \left(\dot{W}_{SOFC,DC}/500 \right)^{0.7}$	Inverter

* $i_r=0.12$, $n=20$ years, $\tau=8000h$, $T=$ retention time in digester, $c_F=2\$/GJ$ (biomass)

Table 6. Exergy and exergy destruction rates for two proposed SOFC systems			
Digester Coupled SOFC		Gasifier Coupled SOFC	
Exergy rate	$\dot{E}X(kW)$	Exergy rate	$\dot{E}X(kW)$
Input exergy	462.6	Input exergy	290.3
Destruction		Destruction	
Digester	41.98	Gasifier	74.42
Air blower	7.018	Air blower	3.591
Fuel blower	0.128	Fuel blower	0.3248
AHX	78.67	AHX1	16.29
FHX	4.716	AHX2	35.3
Stack	42.29	Stack	9.304
AB	30.67	AB	12.95
Mixing unit	2.804	Mixing unit	1.018
HRSG	4.840	HRSG	9.786
Pump	0.049	Pump	0.010
Exergy associated with heating	26.27	Exergy associated with heating	54.29
Exergy associated with power	164.3	Exergy associated with power	49.81
Exergy loss	58.7	Exergy loss	26.93
$U_f=0.80, T_{stack} = 800\text{ }^{\circ}C$			

930

931

Table 7 Exergoeconomic analysis results for the gasifier coupled SOFC (G-SOFC)

Components	$\dot{E}_f$ (kW)	$C_{F,k}$ (\$/GJ)	$C_{P,k}$ (\$/GJ)	$\dot{C}_{D,k}$ (\$/h)	$\dot{C}_{L,k}$ (\$/h)	$\dot{Z}_k$ (\$/h)	$\dot{C}_{D,k} + \dot{C}_{L,k} + \dot{Z}_k$ (\$/h)	f_k (%)
SOFC stack	437	16.8	20.05	0.5627	0	4.430	5.00	88.75
Air heat exchanger 1	15.36	4.751	27.87	0.2142	0	0.022	0.236	9.41
Air heat exchanger2	221.9	21.14	26.52	2.974	0	0.567	3.541	16.02
Air blower	15.62	20.05	34.01	0.2592	0	0.345	0.604	57.15
Fuel blower	6.25	20.05	29.92	0.0234	0	0.187	0.210	88.87
After burner	298.8	20.05	21.14	0.9345	0	0.191	1.126	16.99
Gasifier	260.8	2	3.968	0.5358	0	0.839	1.375	61.04
HRSG	37.06	21.14	33.84	0.7448	2.05	0.502	3.296	15.23
pump	0.0405	20.05	67.06	0.0007	0	0.004	0.005	85.78
$U_f=0.80, T_{stack} = 800\text{ }^{\circ}\text{C}$								

932

933

Table 8 Exergoeconomic analysis results for the digester coupled SOFC (D-SOFC)

Components	$\dot{E}_f$ (kW)	$C_{F,k}$ (\$/GJ)	$C_{P,k}$ (\$/GJ)	$\dot{C}_{D,k}$ (\$/h)	$\dot{C}_{L,k}$ (\$/h)	$\dot{Z}_k$ (\$/h)	$\dot{C}_{D,k} + \dot{C}_{L,k} + \dot{Z}_k$ (\$/h)	f_k (%)
SOFC stack	911.8	9.172	11.04	1.397	0	5.834	5.846	76.06
Air heat exchanger	441.8	11.87	15.28	3.361	0	1.130	4.452	24.51
fuel heat exchanger	12.81	11.87	19.44	0.2015	0	0.058	0.220	8.732
Air blower	30.53	11.04	20.73	0.2788	0	0.541	0.820	66.01
Fuel blower	0.753	11.04	33.46	0.0051	0	0.045	0.050	89.88
After burner	561.5	11.04	11.87	1.219	0	0.370	1.589	23.31
digester	444.4	2	2.277	0.3039	0	0.097	0.401	24.22
HRSG	18.04	11.87	25.23	0.2068	2.50	0.428	3.143	13.62
pump	0.014	11.04	64.49	0.0001	0	0.002	0.002	93.11
$U_f=0.80, T_{stack} = 800\text{ }^{\circ}\text{C}$								

934

935

936

937

Table 9. Comparison of the published works results with those of the present work

Research	Plant Type; Plant Scale	Fuel; Process; Gas	Thermodynamic analysis		Economic analysis	Year
			1 st law Efficiency (%)	2 nd law Efficiency (%)	Unit Product Cost	
Omosun et al. [14]	Cogeneration (Heat and power); 200kW _{el}	Biomass; Fluidized bed gasification; Syngas (17% H ₂ , 13% CO, 11% CO ₂ , 4% CH ₄ , 15% H ₂ O, 40% N ₂)	Electrical: 22.6% Total: 59.6%	-	2.9k £/kW _e 1.1k £/kW _T	2004
Piroonlerkgul et al. [26]	Mono generation (power); small size (50-60kW)	Biogas (60% CH ₄ , 40% CO ₂)	Electrical: 59%	-	-	2008
Farhad et al. [56]	Cogeneration (Heat and power); small size (~1kW _{el})	Biogas (60.8% CH ₄ , 34.8% CO ₂ , 2.4% N ₂ , 1.2% O ₂ , 0.01% water)	Electrical: 22.6% Total: 59.6%	-	-	2010
Bang-Møller et al. [57]	Cogeneration (Heat and power) Hybrid system; medium size (~300kW)	Wood; two-stage gasification; syngas	Electrical: 58.2% Total: 87.5%	Electrical: 50.4% Total: 53.4%	-	2011
Santarelli et al. [29]	Cogeneration (Heat and power); medium size (scale-up 250kW)	Wheat straw; Two- stage anaerobic digester; biogas (55% CH ₄ , 10% H ₂ , 35% CO ₂)	Electrical: 49.2% Total: 75.1%	-	-	2012
El-Emam et al. [58]	Mono generation (power) Hybrid system; Large size (~30MW)	Coal gasification; syngas(10.6% CO ₂ , 51.6 % CO, 0.1% CH ₄ , 35.1% H ₂ , 2.6% N ₂)	Electrical: 38.1%	Electrical: 27%	-	2012
Wongchanapai et al. [59]	Mono generation (power); small scale (5kW)	Wood; two-stage gasification; Syngas(18.7% H ₂ , 21.87 CO, 0.22% CH ₄ , 10.51% CO ₂ , 47.3% N ₂)	Electrical: 38.9%	Electrical: 37.4%	-	2012
Campitelli et al. [60]	Mono generation (power); small scale (1-2 kW)	Wood; autothermal gasification; syngas (17.8% H ₂ , 9.4% CO, 14 % CO ₂ , 19.8% H ₂ O, 0.1% CH ₄)	Electrical: 24.7%	-	-	2013
Arteaga-Pérez et	Cogeneration	Sugar cane/rice husk;	Total:	Total:	-	2013

al. [61]	(Heat and power); medium size (456.5kW)	bubbling fluidized bed gasification; syngas (17.5% H ₂ O, 40.1% N ₂ , 0.6% O ₂ , 6.5% CH ₄ , 13.6% CO, 12.4% CO ₂ , 9.3% H ₂)	55.48%	32.01%		
Morandin et al. [62]	Cogeneration (Heat and power) Hybrid system; small size (~40kW)	Wood; fluidized bed gasifier/Viking gasifier; syngas	Total: 63% (For Viking gasifier case) Total: 58% (For fluidized bed gasifier)	-	15000\$/kW (For Viking gasifier case) 8000 \$/kW (For fluidized bed gasifier)	2013
Trendewicz and Braun [31]	Cogeneration (Heat and power); small, medium and large sizes (330kW, 1530kW, 6140kW)	Waste water; anaerobic digestion; biogas (56.6% CH ₄ , 36.7% CO ₂ , 5.8% H ₂ O)	Electrical: 51.6% Total: 87.5%	-	3584 \$/kW (large size) 3916 \$/kW (medium size) 5780 \$/kW (small size)	2013
Gandiglio et al. [28]	Trigeneration (Heat, power and Algae production); small scale (2kW _{el})	Waste water; anaerobic digester; biogas (60% CH ₄ , 40% CO ₂)	Electrical: 52.56% Total: 85.93%	-	-	2014
Siefert and Litster [33]	Mono generation (power)	Waste water; anaerobic digestion; Biogas (45% CH ₄ , 40% CO ₂ , 15% H ₂ O)	-	Electrical: 58%	3610 \$/kW	2014
Ozcan and Dincer [63]	Trigeneration (Heat, power and cooling); medium size (145.5kW)	ThermoChem bubbling fluidized bed gasifier; syngas (43.3% H ₂ , 9.2% CO, 28% CO ₂ , 5.6% H ₂ O, 4.7% CH ₄)	Electrical: 42.2% Total: 78.8%	Electrical: 36.5% Total: 50.6%	-	2014
Caliandro et al. [64]	Mono generation (power) Hybrid system; small and medium sizes (103kW and 8000kW)	Wood; fast internally circulating fluidized bed gasifier/circulating fluidized bed gasifier/Viking gasifier; syngas	Electrical: 71% (circulating fluidized bed) Electrical: 68.7% (Viking gasifier)	-	0.3 \$/kWh (circulating fluidized bed-medium size) 1.1 \$/kWh (Viking gasifier-small size)	2014
Jia et al. [22]	Cogeneration (Heat and power)	Wood; downdraft gasifier; syngas	Electrical: 42.94%	-	-	2015

	power) Hybrid system; small size (~40kW)		Total: 67.59%			
Curletti et al. [65]	Mono generation (power); large size (1MW _{el})	Waste water; anaerobic digestion; biogas	Electrical: 58.85%	-	2.75 M\$ Net present value	2015
Mehr et al. [34]	Mono generation (power); medium size (~400kW)	Biogas (50-70%CH ₄ ,30%- 50% CO ₂)	Electrical: 46.09%	Electrical:43 .92%	19.53 \$/GJ	2015
Lv et al. [66]	Mono generation (power) Hybrid system; small size (182kW)	Wood; gasification; syngas(4.53% CH ₄ ,23.6 4% H ₂ ,13.87% CO,17.9 2% CO ₂ ,40.04% N ₂)	Electrical: 60.78%	-	-	2016
Present work	Cogeneration (Heat and power); small size	Municipal solid waste; downdraft gasifier; Syngas	Electrical: 20.31%	Electrical: 18.01%	24.69\$/GJ	-
			Total: 58.75%	Total: 28.48%		
		Municipal solid waste ;anaerobic digestion; biogas	Electrical: 40.14%	Electrical:35 .61%	14.17\$/GJ	-
			Total: 51.07%	Total: 38.58%		

940

941

942

943

944

945

946

Table A.1. Material Resistivity used for ohmic voltage loss estimation [52]

Component	Material	Resistivity	Thickness (mm)
Anode	Ni/YSZ cermet	$\rho_{an}=2.98 \times 10^{-5} \exp(\frac{-1392}{T_{FC,e}})$	0.5
Cathode	LSM-YSZ	$\rho_{cat}=8.114 \exp(\frac{600}{T_{FC,e}})$	0.05
Electrolyte	YSZ	$\rho_{ely}=2.94 \times 10^{-5} \exp(\frac{10350}{T_{FC,e}})$	0.01
Interconnection	Doped LaCrO3	0.0003215	-

Table A.2. Parameters correspond to anode and cathode sides material [52]

Component	Parameter	Value	Unit
Anode	Pre-exponential factor for anode, γ_{an}	6.54×10^{11}	A/m^2
	Activation energy for anode, $E_{a,an}$	140,000	J/mol
Cathode	Pre-exponential factor for cathode, γ_{ca}	2.35×10^{11}	A/m^2
	Activation energy for cathode, $E_{a,cat}$	137,000	J/mol