

Perturbative Reformulation of the Stochastic Galerkin Method for Statistical Analysis of Wiring Structures with Several Random Parameters

Original

Perturbative Reformulation of the Stochastic Galerkin Method for Statistical Analysis of Wiring Structures with Several Random Parameters / Wu, X., Grassi, F., Pignari, S.A., Manfredi, P., Vande Ginste, D.. - ELETTRONICO. - (2018), pp. 170-174. (2018 IEEE Symposium on Electromagnetic Compatibility, Signal Integrity and Power Integrity (EMC, SI & PI 2018) Long Beach, CA, USA 2018) [10.1109/EMCSI.2018.8495353].

Availability:

This version is available at: 11583/2759432 since: 2019-10-08T13:14:46Z

Publisher:

Institute of Electrical and Electronics Engineers Inc.

Published

DOI:10.1109/EMCSI.2018.8495353

Terms of use:

This article is made available under terms and conditions as specified in the corresponding bibliographic description in the repository

Publisher copyright

(Article begins on next page)

Perturbative Reformulation of the Stochastic Galerkin Method for Statistical Analysis of Wiring Structures with Several Random Parameters

Xinglong Wu, Flavia Grassi

and Sergio A. Pignari

*Dept. of Electronics, Information and
Bioengineering, Politecnico di Milano*

Milan, Italy

{xinglong.wu;flavia.grassi;
sergio.pignari}@polimi.it

Paolo Manfredi

Dept. of Electronics and

Telecommunications, Politecnico di Torino

Turin, Italy

paolo.manfredi@polito.it

Dries Vande Ginste

Dept. of Information Technology,

IDLab, Ghent University - imec

Ghent, Belgium

dries.vandeginste@ugent.be

Abstract—In this paper, a novel approach for statistical analysis of cable harnesses characterized by several random parameters is proposed, which is based on a perturbative reformulation of the well-known stochastic Galerkin method (SGM). With respect to the traditional SGM, the proposed method avoids the solution of an augmented multiconductor transmission line (MTL), whose dimensions may become prohibitive in case of structures characterized by several wires and random parameters. Namely, it resorts to the iterative and repeated solution of a MTL having the same number of wires as the original structure, where the effects of random variations of geometrical parameters are included by means of equivalent sources. The proposed approach is here applied to collect statistical information of voltages and currents at the terminations of a shielded cable. Through such an example, involving a large number of wires (7) and random variables (12), it is proven that the proposed method yields a significant reduction of computational time with respect to the traditional SGM, at the same time providing similar accuracy in the prediction of statistical moments.

Index Terms—Multiconductor transmission lines, perturbation technique, shielded cable, statistical analysis, stochastic Galerkin method.

I. INTRODUCTION

Statistical techniques recently gained increasing attention from the electromagnetic compatibility (EMC) community, owing to the need for handling systems in which some parameters may randomly vary, due to either manufacturing tolerances or uncertainty in the knowledge of their exact value. This is, for instance, the case of complex wiring harnesses, whose geometrical characteristics, such as precise position of wires within the bundle, are often hard to control [1]–[4]. Since these random variations may significantly impact the EMC performance, modeling and propagating the uncertainty associated with these parameters become of paramount importance to provide a statistical characterization (in terms of statistical moments) of relevant electrical quantities.

To this end, the standard approach, known as Monte Carlo (MC) method, is to perform repeated simulations exploiting different realizations of the system under analysis. However,

in order to achieve a high accuracy in the prediction of statistical moments, a huge number of samples is required. This often leads to an unacceptable computational time, unless the underlying deterministic model is very simple.

To overcome such a limitation without degrading prediction accuracy, more advanced statistical techniques have been recently proposed. Among these, the stochastic Galerkin method (SGM) offers characteristics that are particularly suited for an accurate statistical assessment of cables and interconnects with geometry affected by uncertainty [5]. This method resorts to a polynomial chaos expansion (PCE) of the random quantities of the problem, i.e., the per-unit-length (p.u.l.) parameters (input quantities) as well as line voltages and currents (output quantities). These quantities are expanded in series of orthogonal polynomials, which are then used to derive an augmented, yet deterministic model of the original system, whose solution directly provides statistical estimates of the output variables without the need for repeated simulations. When applied to wiring structures characterized by a limited number of wires and/or random variables, this technique was proven to be very accurate and computationally efficient [6].

Nevertheless, due to its intrusiveness, the computational burden of SGM becomes prohibitive when the number of random variables and/or conductors is very large. To overcome this limitation, the present paper proposes a reformulation of the SGM, which is obtained by combining the classical SGM with the perturbative technique recently proposed in [7], [8] for the solution of nonuniform transmission lines. According to this novel approach, the solution of the augmented multiconductor transmission line (MTL) model obtained by the SGM is avoided, by converting such an augmented network into sub-networks having the same number of wires as the original structure. The solution is achieved iteratively, by including the effects of random variability of geometrical parameters by means of distributed current and voltage sources. The accuracy and computational efficiency of this “hybrid” procedure are here investigated considering a shielded cable with random




Fig. 1: Cross-section of the shielded cable under analysis (a); cable configuration with terminations (b).

position of the inner wires [9], [10] as an application example.

II. STRUCTURE UNDER ANALYSIS

For illustration purposes, we consider in this work the shielded cable depicted in Fig. 1(a). The geometry was originally described in [9]. Later, this cable was stochastically studied in [10]. The cable consists of seven coated wires, with conductor radius r_c and dielectric radius $r_d = 2r_c$. One wire is located at the center of the shield, whereas the remaining six wires lie symmetrically around the center at a radial distance $d = 5r_c$. The relative permittivity of the dielectric coating is $\epsilon_r = 4$. The shield radius is $r_s = 10r_c$.¹ The cable is 4-meter long and uniform along its length. Without loss of generality, in this work we consider a differential source connected between wires no. 1 and no. 2, and 50- Ω loads connected to each wire as depicted in Fig. 1(b).

For the stochastic analysis, the positions of the outer wires (no. 2 to no. 7) are considered to be random. Namely, the horizontal and vertical coordinates of these wires are uniformly distributed within $\pm 10\%$ around their nominal values. The total number of random variables is thus 12.

III. STATE-OF-THE-ART GALERKIN APPROACH

The frequency-domain equations for the cable under investigation read [11]:

$$\frac{d}{dz} \mathbf{V}(z, \omega, \boldsymbol{\xi}) = -j\omega \mathbf{L}(\boldsymbol{\xi}) \mathbf{I}(z, \omega, \boldsymbol{\xi}), \quad (1a)$$

$$\frac{d}{dz} \mathbf{I}(z, \omega, \boldsymbol{\xi}) = -j\omega \mathbf{C}(\boldsymbol{\xi}) \mathbf{V}(z, \omega, \boldsymbol{\xi}), \quad (1b)$$

¹Since only relative dimensions count, the value of r_c is here arbitrary.

where ω is the angular frequency, and \mathbf{L} and \mathbf{C} are the pertinent p.u.l. inductance and capacitance matrices, respectively. Vectors $\mathbf{V} = [V_1, \dots, V_7]^T$ and $\mathbf{I} = [I_1, \dots, I_7]^T$ collect the line voltages and currents, respectively, whereas vector $\boldsymbol{\xi} = [\xi_1, \dots, \xi_{12}]$ encompasses the random parameters (i.e., the wire positions). The p.u.l. inductance and capacitance matrices depend on $\boldsymbol{\xi}$ and they are therefore stochastic, as a result of the variability of wire positions. Due to this randomness, wire voltages and currents are in turn also stochastic.

The classical MC approach collects statistical information by repeatedly solving (1) for multiple samples of the random parameters. However, the MC analysis is rather slow due to the non-negligible time required by the evaluation of the p.u.l. parameters, and by the analysis of the corresponding transmission-line configurations.

In order to significantly speed-up the p.u.l. parameter extraction, a third-order PCE was calculated in [10] to statistically characterize the p.u.l. parameters:

$$\mathbf{L} = \sum_{k=0}^{454} \mathbf{L}_k \varphi_k(\boldsymbol{\xi}) \quad (2a)$$

$$\mathbf{C} = \sum_{k=0}^{454} \mathbf{C}_k \varphi_k(\boldsymbol{\xi}), \quad (2b)$$

where the basis functions φ_k are multivariate Legendre polynomials. From the PCE, relevant statistical information is readily derived [12]. The number of 455 PCE coefficients results from a third-order expansion with 12 random parameters.

Once the PCEs of the p.u.l. parameters are obtained, equations (1) are recast in terms of an augmented and deterministic MTL-like equations by means of the SGM [6]:

$$\frac{d}{dz} \tilde{\mathbf{V}}(z, \omega) = -j\omega \tilde{\mathbf{L}} \tilde{\mathbf{I}}(z, \omega), \quad (3a)$$

$$\frac{d}{dz} \tilde{\mathbf{I}}(z, \omega) = -j\omega \tilde{\mathbf{C}} \tilde{\mathbf{V}}(z, \omega), \quad (3b)$$

where vectors $\tilde{\mathbf{V}}$ and $\tilde{\mathbf{I}}$ collect the PCE coefficients of the wire voltages and currents, whereas the new p.u.l. matrices $\tilde{\mathbf{L}}$ and $\tilde{\mathbf{C}}$ are formed by a suitable combination of the PCE coefficients in (2). By solving the deterministic MTL problem (3), a statistical characterization of the voltages and currents in terms of PCEs like (2) is obtained. Equation (3) is 455 times larger than (1), therefore being equivalent to a line with 3185 conductors instead of 7! This is the so-called ‘‘curse of dimensionality’’, which reduces the efficiency of the SGM for problems with high order and/or number of random parameters.

IV. PROPOSED PERTURBATIVE GALERKIN APPROACH

In order to alleviate the computational burden of the direct solution of (3) as a (rather huge) coupled MTL, a perturbation technique is applied in order to solve the SGM problem (3) in an iterative and decoupled manner. This perturbation technique is a reformulation of the one originally proposed in [7, 8] for the analysis of nonuniform MTLs.

The proposed approach starts by isolating the first component in the PCEs (2), which corresponds to the average value and is constant w.r.t. ξ , being $\varphi_0(\xi) = 1$:

$$\mathbf{L} = \mathbf{L}_0 + \sum_{k=1}^{454} \mathbf{L}_k \varphi_k(\xi) \quad (4a)$$

$$\mathbf{C} = \mathbf{C}_0 + \sum_{k=1}^{454} \mathbf{C}_k \varphi_k(\xi) \quad (4b)$$

With this modification, the SGM produces

$$\frac{d}{dz} \tilde{\mathbf{V}}(z, \omega) = -j\omega \begin{bmatrix} \mathbf{L}_0 & & \\ & \ddots & \\ & & \mathbf{L}_0 \end{bmatrix} \tilde{\mathbf{I}}(z, \omega) - j\omega \widetilde{\Delta \mathbf{L}} \tilde{\mathbf{I}}(z, \omega) \quad (5a)$$

$$\frac{d}{dz} \tilde{\mathbf{I}}(z, \omega) = -j\omega \begin{bmatrix} \mathbf{C}_0 & & \\ & \ddots & \\ & & \mathbf{C}_0 \end{bmatrix} \tilde{\mathbf{V}}(z, \omega) - j\omega \widetilde{\Delta \mathbf{C}} \tilde{\mathbf{V}}(z, \omega), \quad (5b)$$

where the diagonal matrices in the r.h.s. are the result of the Galerkin projection of the deterministic, zero-order components, whereas the augmented matrices $\widetilde{\Delta \mathbf{L}}$ and $\widetilde{\Delta \mathbf{C}}$ are structurally identical to $\tilde{\mathbf{L}}$ and $\tilde{\mathbf{C}}$ in (3). Yet, they do not account for the aforementioned average contributions, but only for the random displacement therefrom.

It should be noted that the norms of $\widetilde{\Delta \mathbf{L}}$ and $\widetilde{\Delta \mathbf{C}}$ are expected to be (significantly) smaller than the norms of \mathbf{L}_0 and \mathbf{C}_0 . This is because the expansions (2) are convergent, and the norms of their coefficients decay exponentially to zero [12]. This interpretation allows solving equation (5) iteratively by resorting to a perturbation approach [7, 8]. By denoting with the subscript m the solution at the m th iteration step, equation (5) becomes

$$\frac{d}{dz} \tilde{\mathbf{V}}_m(z, \omega) = -j\omega \begin{bmatrix} \mathbf{L}_0 & & \\ & \ddots & \\ & & \mathbf{L}_0 \end{bmatrix} \tilde{\mathbf{I}}_m(z, \omega) - j\omega \widetilde{\Delta \mathbf{L}} \tilde{\mathbf{I}}_{m-1}(z, \omega), \quad (6a)$$

$$\frac{d}{dz} \tilde{\mathbf{I}}_m(z, \omega) = -j\omega \begin{bmatrix} \mathbf{C}_0 & & \\ & \ddots & \\ & & \mathbf{C}_0 \end{bmatrix} \tilde{\mathbf{V}}_m(z, \omega) - j\omega \widetilde{\Delta \mathbf{C}} \tilde{\mathbf{V}}_{m-1}(z, \omega). \quad (6b)$$

The above equation is equivalent to an MTL with distributed sources (cfr. [11]). It is important to remark that such distributed sources depend only on the solution at the previous iteration step, and they are therefore known when solving (6) at step m . Moreover, the MTL is now described by block

diagonal p.u.l. matrices. This allows solving each block independently by considering

$$\frac{d}{dz} \mathbf{V}_{k,m}(z, \omega) = -j\omega \mathbf{L}_0 \mathbf{I}_{k,m}(\omega) + \mathbf{V}_{Fk,m}(z, \omega), \quad (7a)$$

$$\frac{d}{dz} \mathbf{I}_{k,m}(z, \omega) = -j\omega \mathbf{C}_0 \mathbf{V}_{k,m}(\omega) + \mathbf{I}_{Fk,m}(z, \omega) \quad (7b)$$

for $k = 0, \dots, 454$, where

$$\mathbf{V}_{Fk,m} = [-j\omega \widetilde{\Delta \mathbf{L}}_k \tilde{\mathbf{I}}_{k,m-1}(z, \omega)]_{k\text{th row block}} \quad (8a)$$

$$\mathbf{I}_{Fk,m} = [-j\omega \widetilde{\Delta \mathbf{C}}_k \tilde{\mathbf{V}}_{k,m-1}(z, \omega)]_{k\text{th row block}} \quad (8b)$$

The problem (6) is solved for increasing m starting from null equivalent sources and updating them with (8), until the solution has converged within a given tolerance (0.1% in this paper). Thereafter, the vectors of PCE coefficients $\tilde{\mathbf{V}}$ and $\tilde{\mathbf{I}}$ are obtained as the sum of all the computed perturbation terms.

The new proposed approach requires the solution of MK equivalent MTL problems of size n (i.e., the number of conductors of the original transmission line), with M the total number of perturbation steps and K the number of PCE coefficients. This is opposed to the single simulation of an MTL of size nK . Therefore, although the number of perturbations M may vary with frequency and with the amount of variation in the line parameters, the proposed method is expected to outperform the classical SGM when the number of conductors and/or PCE coefficients is large, as is the case for the shielded cable of Fig. 1, for which $n = 7$ and $K = 455$.

V. NUMERICAL RESULTS AND VALIDATION

In this section, the proposed perturbative technique is compared against the classical SGM implementation in the computation of the mean and standard deviation of some explicative examples of voltages at the terminations of the shielded cable of Fig. 1. The PCE of the p.u.l. inductance and capacitance matrices are taken from [10]. Their augmented counterparts $\tilde{\mathbf{L}}$ and $\tilde{\mathbf{C}}$ are readily obtained. The simulations are performed on a PC with an Intel(R) Core(TM) i7-6700, CPU running at 3.4 GHz and 16 GB of RAM.

As an example, Fig. 2 illustrates the common mode (CM) voltage at the near end (top left) and the differential mode (DM) voltage at the far end (top right) of the two conductors used for differential signaling, as well as the induced single-ended crosstalk voltages on conductors no. 3 at the near end (bottom left) and no. 5 at the far end (bottom right). The comparison between the classical SGM (solid gray lines) and the proposed perturbative SGM (dashed black lines) shows excellent agreement, thus proving the accuracy of the proposed approach.

As far as computational efficiency is concerned, the perturbative SGM only requires 2463 s to analyze 500 frequency points, in contrast to the 24079 s required by the classical SGM. A speed-up factor of roughly one order of magnitude is thus achieved. This is remarkable when considering that the perturbative approach requires to deal with additional distributed sources, in analogy with the analysis of nonuniform MTLs (cfr. [7]), even for a uniform MTL. For this reason, the




Fig. 2: Mean and standard deviation of (a) CM voltage at near end of wires no. 1 and 2, (b) DM voltage at far end of wires no. 1 and 2, (c) crosstalk voltage at near end of wire no. 3 and (d) crosstalk voltage at far end of wire no. 5 predicted by the standard SGM method (solid grey curves) and by the proposed approach (dashed black curves).

proposed method is expected to be even more beneficial for nonuniform MTLs.

It should be mentioned that the time required to compute the PCE of the p.u.l. parameters is excluded from the above analysis, since it is a one-off preliminary step that is common to both SGM-based approaches, and it does not need to be re-performed when different terminal configurations and/or cable lengths are considered.

VI. CONCLUSION

This work presented a hybrid technique for the statistical analysis of wiring harnesses affected by several random geometrical parameters. The proposed approach is based on a perturbative reformulation of the traditional SGM, and allows keeping the size of the MTL networks to be solved equal to the size of the original MTL structure under analysis.

According to such a perturbative approach, an initial prediction of the voltage and current PCE coefficients is first evaluated using the average of the p.u.l. parameters. Then, these values are iteratively refined by including distributed voltage and current sources that involve the stochastic variation of the p.u.l. parameters through their PCE coefficients.

The proposed approach has been applied to the statistical assessment of a shielded cable involving a large number of wires (7) and random parameters (12). With respect to traditional SGM implementations, the advocated technique has proven to provide a significant reduction of computational time, while retaining similar prediction accuracy.

Finally, it is worth mentioning that, although here applied to uniform MTLs only, the proposed approach appears to be promising (and even more beneficial) to handle the practically relevant case of wiring harnesses or interconnects with cross-section that randomly vary along the line length.

REFERENCES

- [1] M. Wu, D. G. Beetner, T. H. Hubing, H. Ke, and S. Sun, "Statistical prediction of reasonable worst-case crosstalk in cable bundles," *IEEE Trans. Electromagn. Compat.*, vol. 51, no. 3, pp. 842–851, 2009.
- [2] C. Jullien, P. Besnier, M. Dunand, and I. Junqua, "Crosstalk analysis in complex aeronautical bundle," in *Proc. 2013 Int. Symp. on Electromagn. Compat.*, Bruges, Belgium, Sep. 2013, pp. 253–258.
- [3] F. Paladian, P. Bonnet, and S. Lall  ch  re, "Modeling complex systems for emc applications by considering uncertainties," in *Proc. 2011 XXX URSI General Assembly and Scientific Symp.*, Istanbul, Turkey, Aug. 2011, pp. 1–4.
- [4] G. Spadacini, F. Grassi, and S. A. Pignari, "Field-to-wire coupling model for the common mode in random bundles of twisted-wire pairs," *IEEE Trans. Electromagn. Compat.*, vol. 57, no. 5, pp. 1246–1254, 2015.
- [5] I. S. Stievano, P. Manfredi, and F. G. Canavero, "Stochastic analysis of multiconductor cables and interconnects," *IEEE Trans. Electromagn. Compat.*, vol. 53, no. 2, pp. 501–507, 2011.

- [6] P. Manfredi, D. Vande Ginste, I. S. Stievano, D. De Zutter, and F. G. Canavero, "Stochastic transmission line analysis via polynomial chaos methods: an overview," *IEEE Electromagn. Compat. Mag.*, vol. 6, no. 3, pp. 77–84, 2017.
- [7] P. Manfredi, D. De Zutter, and D. Vande Ginste, "Analysis of nonuniform transmission lines with an iterative and adaptive perturbation technique," *IEEE Trans. Electromagn. Compat.*, vol. 58, no. 3, pp. 859–867, 2016.
- [8] X. Wu, F. Grassi, P. Manfredi, and D. Vande Ginste, "Perturbative analysis of differential-to-common mode conversion in asymmetric nonuniform interconnects," *IEEE Trans. Electromagn. Compat.*, vol. 60, no. 1, pp. 7–15, 2018.
- [9] S.-K. Chang, T. K. Liu, and F. M. Tesche, "Calculation of the per-unit length capacitance matrix for shielded insulated wires." *Technical Report, Science Applications Inc. Berkeley Calif, AD-A048*, 1977.
- [10] P. Manfredi and F. Canavero, "Efficient statistical extraction of the per-unit-length capacitance and inductance matrices of cables with random parameters," *Advanced Electromagnetics*, vol. 4, no. 1, pp. 22–30, 2015.
- [11] C. R. Paul, *Analysis of multiconductor transmission lines*. John Wiley & Sons, 2008.
- [12] D. Xiu and G. E. Karniadakis, "The Wiener-Askey polynomial chaos for stochastic differential equations," *SIAM J. Sci. Comput.*, vol. 24, no. 2, pp. 619–644, 2002.