

Optimal Management of Network Integrated EV Batteries by Individual EV Usage Forecasts: Vehicle to Home and Vehicle to Grid Case Studies

Original

Optimal Management of Network Integrated EV Batteries by Individual EV Usage Forecasts: Vehicle to Home and Vehicle to Grid Case Studies / Giordano, Francesco. - (2021 Apr 23), pp. 1-139.

Availability:

This version is available at: 11583/2898046 since: 2021-05-04T10:14:14Z

Publisher:

Politecnico di Torino

Published

DOI:

Terms of use:

Altro tipo di accesso

This article is made available under terms and conditions as specified in the corresponding bibliographic description in the repository

Publisher copyright

(Article begins on next page)

Summary

Francesco Giordano

Optimal Management of Network Integrated EV Batteries by Individual EV Usage Forecasts: Vehicle to Home and Vehicle to Grid Case Studies

The growing attention in sustainability and environmental problems is driven by deep changes in entire sectors. Among others, the transport and the power sectors will assist to the greater transformation in the next years. As a result, recent lines of research are studying the use of Electric Vehicles (EVs) as sources of grid flexibility as well as their effects on the energy balance of users equipped with charging station and Photovoltaic (PV) generators.

This dissertation presents a novel approach to exploit and control the EV batteries of network integrated vehicles using individual EV forecasts. The approach is based on a bilevel programming where the real-time management is integrated by a preliminary optimization phase. On the other hand, the EV forecasts rely on statistical elaborations of real EVs usages historical data. Moreover, the proposed approach has been declined in two different case studies with different purposes.

The first case study regards the integration of an EV in a PV powered household, thus aims to maximize the obtainable PV self-consumption and self-sufficiency. The second case study considers an entire fleet of 214 EVs connected into the power system and able to supply grid services such as Replacement Reserve and Secondary Regulation. The objective of this latest case is to maximize the economic benefit achievable from the bidirectional power exchanges of the EVs fleet from and toward the grid. In both case studies, the results are presented in comparison with specific logics assumed as reference in order to evaluate the effectiveness of the proposed methodology.