### POLITECNICO DI TORINO Repository ISTITUZIONALE

Numerical and experimental analysis of thermal behaviour of high voltage power cable in unfilled ducts

Original

Numerical and experimental analysis of thermal behaviour of high voltage power cable in unfilled ducts / Quercio, M.; Del Pino Lopez, J. C.; Grasso, S.; Canova, A.. - In: SCIENTIFIC REPORTS. - ISSN 2045-2322. - 14:1(2024). [10.1038/s41598-024-71281-x]

Availability: This version is available at: 11583/2995413 since: 2024-12-16T09:20:13Z

*Publisher:* Nature Research

Published DOI:10.1038/s41598-024-71281-x

Terms of use:

This article is made available under terms and conditions as specified in the corresponding bibliographic description in the repository

Publisher copyright

(Article begins on next page)

# scientific reports

Check for updates

# **OPEN** Numerical and experimental analysis of thermal behaviour of high voltage power cable in unfilled ducts

Michele Quercio<sup>1⊠</sup>, Juan Carlos Del Pino Lopez<sup>2</sup>, Sergio Grasso<sup>3</sup> & Aldo Canova<sup>4</sup>

The work addresses the topic of the thermal study of high-voltage power cables installed inside plastic pipes in the absence of filling. The presence of air inside the pipe creates an insulating layer that does not favor heat exchange and makes the calculation of the flow rate more complex, as it is necessary to take into account the thermal phenomena of natural convection and radiation between the surface of the cable and the internal surface of the tube. The numerical model based on the finite element calculation was compared with the experimental results obtained on a simulacrum in which the temperatures on the different layers of the cable were measured. After this validation, some typical installation configurations of single and double energy transport triads were analyzed.

The thermal analysis of electrical cables, with particular reference to high voltage ones, represents an essential phase in the design of an electrical line to evaluate the power line's ampacity. Many factors influence the thermal behavior and, therefore, the ampacity, mainly the physical characteristics of the materials that make up the cable and the type of laying. Based on this information, the equations governing heat transfer may or may not include convection and radiation phenomena in addition to the conductive heat exchange, which is always present. Solution equations are differential equations that can be solved using various analytical or numerical methodologies or a mix of both<sup>1</sup>. In the case of cables laid directly in the ground, the problem is relatively simple and governed by conductive heat exchange equations with a possible convective exchange on the ground's surface. In this case, the analytical methods are reliable and have been used for many years for power line design. The standard IEC 60287<sup>2</sup> establishes the methods of calculating the rated current of the cables in a range of different installation conditions. The analytical equations given in the standard are based on the fundamental theory of heat transfer, while others are empirical or semi-empirical equations derived from "field" experience. The standard includes an empirical approach to determining rated currents for cables in unfilled channels. In many situations, the IEC approach does not consider some environmental parameters or their variation. To improve the ampacity calculation's reliability or the temperature distribution estimation, the numerical integration of the heat transfer equations must be followed. The use of numerical approaches like the Finite Element Method has been adopted since 20 years ago<sup>3-5</sup>, in many cable configurations. Different comparisons have been provided in standard layouts, where the cables are in contact with soil materials. In<sup>6</sup>, where a comparison between the analytical approach, based on IEC formulae, and FEM, is presented, the numerical solution produces more reliable results which better take into account the wind contribution. Analyzing the literature on the paper topic, we observe many works related to heat transfer performance for underground cables, mainly for directly underground cables. On the contrary, studies on cables installed in unfilled pipes are relatively few. The aspects related to heat transfer by convection and radiation have yet to be sufficiently studied from a theoretical and experimental point of view. In the case of cables positioned in free air or inside confined spaces in the air, e.g., pipes or tunnels, convective and radiation heat exchange phenomena also occur, and the complexity of the domains and the equations increases considerably. In this case, analytical methods are challenging to apply, and in the past, semi-empirical methods based on experimental tests have been used. Today, the possibility of exploiting numerical computational codes that implement the described physics allows us to solve these thermal problems more accurately, avoiding an empirical approach. The installation of cable in free air is considered weekly by the standards, which take into account effects like the speed of wind in the direction only selectively. To consider such effects, together with

<sup>1</sup>Roma Tre University, 00146 Rome, Italy. <sup>2</sup>University of Sevilla, 41013 Seville, Spain. <sup>3</sup>Be Shielding S.r.l., 10098 Cascine Vica Rivoli, Italy. <sup>4</sup>Polytechnic University of Turin, 10129 Turin, Italy. <sup>22</sup>email: michele.quercio@ uniroma3.it

solar radiation, the paper<sup>7</sup> presents the impact of selected weather conditions on the current-carrying capacity of power cables. The calculation is based on computational fluid dynamics (CFD) simulations performed using ANSYS Fluent software. A similar approach and the same software, on a more manageable configuration of only one conductor (aerial and without insulation) but in a 3D geometry domain, has been adopted in the paper<sup>8</sup>. In paper<sup>9</sup>, the study of a group of power cables in free air is faced with a numerical approach (COMSOL Multiphysics<sup>10</sup>). The paper proposes a thermal-electrical circuit model for the accurate steady-state rating for the most common installation configurations, and the results are compared with IEC, FEM, and experimental tests. The complexity of the numerical problem, also in terms of time calculation and convergence, increases in the case of cables installed in confined spaces, and in particular, this deals with installing cables inside unfilled plastic conduits. Neher and McGrath made the first evaluations of this type of installation<sup>11</sup> in 1957 and later taken up in the IEC 60287 standard. The paper<sup>12</sup> the numerical analysis of heat dissipation from a set of cables installed on the floor of a shallow trough is analysed. The cover of the concrete trough is exposed to the ambient air and the sun. The floor and the walls, also made of concrete, are in contact with compacted rock and native soil. The paper compares the FEM approach with the IEC standard 60287 and an analytical approach, like Slaninka's method<sup>13</sup>. Recently some papers have presented a numerical approach based on FEM to the study of power cables inside unfilled ducts. First papers<sup>14-16</sup> deal with the case of a three-phase power line installed inside an unfilled pipe. The work is theoretical and shows the influence of some parameters, such as the effect of domain mesh on the distribution of air velocities and temperature and the effect of the vertical position of the cables inside the tube. The papers<sup>17-21</sup> show a significant discrepancy between the IEC standard calculations for steady-state conditions. The comparison was also carried out with experimental tests and FEM simulations. The discrepancies between the experimental evaluations and the regulatory approach are mainly attributable to the calculation of the heat transfer of the air between the surface of the cable and the internal surface of the duct. Starting from the presented state of art<sup>22-35</sup> in this paper, a 2D numerical analysis of three-phase power lines with each cable placed inside a pipe is analyses  $^{36-38}$ . In order to provide proper validation, an experimental setup has been realized, and the model simulation results are compared with the experimental test. In particular, attention has been dedicated to simulating the thermal dissipation linked to convective and radiation contribution. After the validation stage, a numerical parameter analysis of some power line configurations is presented and discussed. The work is structured as follows: "Experimental results of the power cable" section, a description of the power cable model, is introduced, and the experimental setup is described. In "Numerical model" section, the numerical model simulation is discussed. "Comparison between numerical and experimental results" section presents the comparison between numerical and experimental results. Following, "Three-phase configuration" section introduces the three-phase configuration. Finally, conclusions are drawn in "Conclusion" section.

## Experimental results of the power cable Description of the power cable model

The structure of the cable is shown in Figs. 1 and 2, which contains the Aluminium conductor, a layer of XLPE insulation, a layer of aluminum with the function of a shield, and an external PE insulation layer. The picture reports the main dimensions in millimeters. It is a 1600 mm<sup>2</sup> aluminum cable, and under standard installation conditions, it has an ampacity of about 900–1000 A. The thermal properties of the materials for the cable simulations are those reported in the IEC standards 60853-2.



Fig. 1. Power cable dimensions.



Fig. 2. Cross-section cable.

#### Experimental set-up

In Fig. 3 is reported the scheme of the measurement set up where the power cable is inserted inside the duct and is centered along the vertical axis. The vertical position is a parameter  $(D_{int})$  and two positions are chosen in the analysis:  $D_{int} = 0$  and  $D_{int} = \frac{(d_{duct} - d_{cable})}{2}$ .

The other parameter are:  $d_{duct} = 200$ mm and  $th_{duct} = 5$ mm. The total length of the analyzed cable is 4 meters. In order to evaluate the trend over time of the temperature of the various layers of the cable and of the pipe, probes were applied, as shown in Fig. 2. Figures 4, 5 show the set-up used for laboratory tests.

The tests were carried out for two different current values, 1000A, and 1250A, each considered as configuration first the cable in the center of the tube and then the cable resting on the tube. The results are shown in Figs. 6 and 7.

In the tests, when powering the HV cable, the temperature increased at the inlet and outlet points of the current, which propagated towards the center of the cable, falsifying the values acquired by the thermocouples (cable small size). For this reason, a continuous cooling system has been positioned in the cable's two ends, as seen in Fig. 5. By circulating water through the cable, heat generated at the ends of the cable can be dissipated more efficiently, resulting in a more uniform temperature distribution along the length of the cable, as shown in Table 1.

Water cooling systems have been successfully implemented in various high-voltage power cable applications, including submarine and underground cables. These systems typically consist of a closed water loop circulated through the cable using pumps and heat exchangers. The water absorbs heat from the cable and then cools by passing through a heat exchanger before recirculating. Water cooling systems can provide several benefits for high-voltage power cables. First, they can eliminate the end effects that can occur when heat accumulates at the ends of the cable, leading to temperature gradients and potential damage to the insulation. Second, they can improve the overall thermal performance of the cable, allowing it to carry more current without overheating. Finally, they can increase the cable's lifespan by reducing thermal stress and minimizing the risk of insulation failure.



Fig. 3. Set-up measurement.



Fig. 4. Probe positions in the pipe.



Fig. 5. Cable centered inside the thermally insulated pipe.



Fig. 6. Overtemperature with 1000A.



Fig. 7. Overtemperature with 1250A.

Position	T [°C] w/o cooling system	T [°C] w/ cooling system
Left end	120	100
Center	100	100
Right end	120	100

Table 1. Temperature evaluation along the cable in the case of 1250 A cable centered in the tube Conductor 90°.

#### Numerical model

In order to analyze and examine the thermal behavior of the cable under different features and characteristics, a numerical model is designed in the 2D model using the commercial software Comsol<sup>10</sup>. The problem of the cable inside the tube was addressed through two studies: stationary and time-dependent. For each study, a multiphysics problem was solved by considering the physics of Heat Transfer in Solids and Fluids, Turbulent flow, Surface-to-surface radiation, and Laminar flow. For each of them, the boundary conditions have been defined:

1. Heat transfer in solids and fluids: A constant temperature equal to the ambient temperature was set to the external perimeter of the circle representing the external ambient.Furthermore, the conductor of the cable was considered as a heat source in wich the  $Q_0$  is equal to:

$$Q_0 = \frac{W_{cable}}{S_{cable}} \tag{1}$$

Where

a. 
$$W_{cable} = R_{cable} \cdot I_{cable}^2$$

- $W_{cable} = R_{cable} \cdot I_{cable}^{-}$  $S_{cable}$  is the cross-section of the cable b.
- 2. Turbulent flow: This physic was set to the air domain outside the pipe. A Wall boundary condition was selected considering the perimeter of the pipe and that of the external air domain. To consider the pressure constraint a point inside the air region was selected imposing 0 Pa on it.
- Surface-to-surface radiation: Due to the high temperatures, the radiation between cable and pipe and between 3. pipe and the external air domain is also considered.
- Laminar flow: Finally, due to the geometry in the air region between the cable and the pipe, a laminar flow 4. pattern is imposed.

After setting the problem both from a geometric and physical point of view, it was possible to carry out the analyzes first in a steady state and then in the transitory case. The regime of the latter must correspond to the results of the stationary case.

#### Stationary study

This subsection shows the simulations of the experimental case in the stationary condition. Figure 8 shows the operating temperatures of the case at 1000A and at 1250A in the condition of cable in the center of the pipe and resting on it.



**Fig. 8.** Temperatures of the cable respectively with currents of 1000 A and 1250 A centered in the tube and the same with the cable resting in the lower part of the tube (From top to bottom).

#### Time dependent study

The study of the temperature trend as a function of time is shown in Fig. 9. In order not to burden the reading, the values are reported considering only a current of 1000A. For reasons related to the calculation time, a value of 18 h was considered in which the steady state value begins to be reached.

From the graphs shown in the Figs. 8 and 9 it is noted how the steady state values of the transient temperatures coincide with the values of the stationary study. This allows to validate the goodness of the model.



**Fig. 9.** Temperatures Time Dependent Study 1000A cable centered in the tube and cable leaning against the tube.

### Comparison between numerical and experimental results

Figures 10 and 11 show the temperature trends for the cable only in the simulated and experimental case in the cable condition at the center of the pipe for 1000 A and 1250 A. The comparison of the curves shows that the trends differ slightly from the experimental case so that the simulation fully reflects reality. In Tables 2 and 3 are reported to clarify the comparison of the temperature values of each layer of the cable and pipe for the different cases in the steady state condition.

#### Three-phase configuration

Once the numerical model of the cable inside the duct is validated, it is now possible to develop an in-depth parametric analysis on a typical two-circuit underground arrangement. In particular, the system shown in Fig. 12 is the reference case, where the same 1600 mm<sup>2</sup> aluminum conductor employed in previous sections is considered.



Fig. 10. Comparison simulated and experimental data, cable centered in the tube.



Fig. 11. Comparison simulated and experimental data, cable centered in the tube.

			· · · · · · · · · · · · · · · · · · ·	·
Case	1000 A centered Exp., °C	1000 A resting Exp., °C	1000 A centered Sim., °C	1000 A resting Sim., °C
Conductor	56	54	55.8	53.55
Shield	47.77	44.3	47.7	45.5
Insulation	47	44.3	45.3	43
Pipe outer wall	36.1	33	33.3	31.2
Pipe internal wall	35.8	34.2	35.4	32.8

Table 2. Comparison of the temperature between simulated and experimental case (1000 A).

Scientific Reports | (2024) 14:20599 |

Case	1250 A centered Exp., , °C	1250 A resting Exp., , °C	1250 A centered Sim., , °C	1250 A resting Sim., , °C
Conductor	70	70.4	70.3	67.6
Shield	57.3	56.8	57.7	55
Insulation	56.3	55.7	53.4	52
Pipe outer wall	37.6	38.6	36	37
Pipe internal wall	40	41	40	38

 Table 3. Comparison of the temperature between simulated and experimental case (1250 A).





The values of the main parameters of the system are summarized in Table 4, where dp is the burial depth, s the clearance between phases, dc is the clearance between circuits, and Hsoil and Wsoil is the height and width of the soil domain, respectively. Phases arrangement for this case study is also described in Fig. 12, as well as the different boundary conditions applied for the thermal problem, being Tair, the temperature at the air-soil interface, and Tsoil, the soil temperature at a certain depth. In this situation, and assuming shields in single-point configuration, the ampacity of this case study is 883 A (phase current).

In the following, a parametric analysis is developed by varying each parameter in a reasonable range while the rest remain as shown in Table 4.

#### Model assumptions

There are three main aspects to be considered during the modelling stage: the mesh size, the size of the soil domain and the type of boundary conditions to be applied.

#### Mesh size

The mesh size is a crucial point to analyze before starting the parametric analysis since it influences both the computational cost and the accuracy of the results. In this sense, four different mesh sizes have been considered for this case study: coarser, regular, finer and extra fine meshes, as shown in Fig. 13, where mesh elements are progressively reduced for correctly modeling the heat transfer mechanisms involved in the air gaps inside the tubes. The results of this analysis are shown in Fig. 14, where the maximum temperatures obtained for the conductor, shield, and jacked are represented as a function of the mesh size.

As can be seen, using a coarser mesh leads to high errors in the temperature estimation, while a regular mesh provides a good balance between results and simulation time. Finally, using a finer mesh or an extra fine mesh provides more accurate results, but with the main drawback of the computational cost. Consequently, in this study, a regular mesh is considered.

Parameter	Value	Parameter	Value
d <sub>b</sub>	1.6 m	T <sub>soil</sub>	10 °C
S	0.28 m	Wsoil	40 m
d <sub>c</sub>	0.42 m	H <sub>soil</sub>	20 m
T <sub>air</sub>	20 °C	k <sub>soil</sub>	$0.833 \frac{W}{mK}$

**Table 4.** Values for the parameters of Fig. 12.



Fig. 13. Mesh sizes considered in the study.



Fig. 14. Temperature in conductor, shield and jacket depending on the mesh size (phase current of 883 A).

#### Size of the soil domain

The domain size employed for modeling the soil greatly affects the results so that an appropriate size may lead to incorrect results. In this sense, Wsoil and Hsoil have been modified to show this influence on the resulting maximum temperature of the conductors. Results are summarized in Fig. 15, where it can be easily concluded that results are more accurate as the soil dimensions increase, especially the Hsoil. However, this also concludes that Wsoil and Hsoil must be at least 40 m and 20 m, respectively. To avoid using such large dimensions, Comsol Multiphysics includes a feature called "Infinite element domain." This feature can be applied to the soil's most



Fig. 15. Influence of soil domain height and width on the maximum temperature of the conductors (phase current of 883 A).

external layers ("Infinite domain" in Fig. 16), having the effect of stretching it to almost infinity<sup>10</sup>. Consequently, the model's size is reduced, hence its computational cost. The result derived from this assumption is also included in Fig. 15 (red dashed line).

In the following, this feature is employed for the parametric analysis, where Wsoil and Hsoil are reduced to 6 m and 3 m, respectively.

#### Boundary conditions

Regarding the boundary conditions to be applied on the top and bottom boundaries of the system, it is commonly accepted to fix their temperatures at a certain value. Thus, on one hand, it is well-known that the soil temperature remains stable for a certain depth, so fixing the bottom boundary to Tsoil ensures this assumption, providing an alternative cold sink for the thermal problem. On the other hand, to fix the air-soil interface temperature to Tair entails with the Kennelly's hypothesis considered in the IEC 60287 standard<sup>2</sup>. However, it is also possible to include the influence of the air convection mechanism on this boundary, defined by:

$$Q_{conv} = h \cdot (T - T_{air}) \tag{2}$$

being T the temperature at the air-soil interface and h the convection coefficient in  $W/(m^2 K)$ . The impact of these boundary conditions, as well as their main parameters (h and Tair), are shown in Fig. 17, where the solid lines (denoted with "conv.") are the cases where air convection is considered, using dashed lines for those where Tair is fixed at the air-soil interface.

As expected, the maximum temperature of the conductors increases with Tair. However, different behavior is observed depending on the boundary condition applied to the air-soi interface. Thus, as forced convection is more prominent (greater values for h), the resulting maximum temperature gets closer to that derived by fixing the temperature at the air-soil interface. Therefore, when forced convection is expected ( $h > 15 \text{ W/(m}^2 \text{ K})$ ), there are no essential differences in applying any of these boundary conditions. Conversely, from this fig., it can also be concluded that air convection should be carefully considered when natural convection is expected in the actual location, especially for  $h < 5 \text{ W/(m}^2 \text{ K})$ . Hence, for the parametric analysis developed next, Tair is fixed at the air-soil interface.



Fig. 16. Use of the "Infinite domain element" feature in the soil domain.



**Fig. 17.** Influence of air temperature and convection coefficient in the maximum temperature of the conductors (phase current of 883 A).

#### **Cable configuration**

Once all aspects regarding the FEM model are properly set up, it is now possible to analyse the impact of different aspects of the cable configuration. In this sense, relevant aspects such as the phase arrangement, depth of burial, phases and circuits clearance, as well as the influence of the surrounding medium thermal properties.

#### Phases arrangement

The arrangement of the phases may also influence the maximum temperature achieved in the conductors. This is shown in Fig. 18 for three different phase arrangements, where differences about 1 °C are observed in the worst situation (cases shown in Fig. 18a and c), and therefore with almost no impact on the power line ampacity. An alternative layout commonly employed in two-circuits underground power lines is that where each circuit

is laid in trefoil configuration, as shown in Fig. 19. As can be seen, this configuration results in slightly higher







**Fig. 19.** Maximum temperature in the conductors for two circuits in trefoil configuration (phase current of 883 A).

temperature values (less than 0.5 °C in the hottest cable) when compared to the reference case (Fig. 18a), hence barely affecting the current rating that results in 880 A.

Consequently, given the phases and circuits clearances, the phases arrangement has no important effects on the power line ampacity.

#### Tubes in a concrete block

An important aspect that improves the thermal performance of underground power lines is the use of a concrete block when installing the tubes. To analyse its impact on the ampacity a  $1.7 \text{ m} \times 0.7 \text{ m}$  concrete block is employed in the reference case (Fig. 20), with a thermal conductivity of  $1.177 \text{ W}/(\text{m}^2 \text{ K})$ .

In this new configuration, the maximum temperature achieved in the conductors (Fig. 21) is lower than in the reference case (Fig. 18a), so the ampacity rises up to 903 A. This is due to the thermal conductivity of the concrete, that is higher than that of the surrounding soil, enhancing the heat dissipation of the system.

This analysis is also applicable for the trefoil configuration considered in the previous section. In this case, lower values are also obtained for the maximum temperature (Fig. 22) in comparison with those obtained without the presence of the concrete block (Fig. 19), resulting in a line ampacity of 900 A.

The results for the different configurations considered in this analysis, either with or without concrete block, are summarized in Table 5, which included the resulting ampacity (Imax) for each situation.

#### Circuit's and phase's clearances

The clearance between phases and circuits (s and dc in Fig. 23) is very important in thermal heating. The influence of both parameters on the maximum temperature achieved in the phase conductors is shown in Fig. 23. As expected, the temperature rises when reducing these clearances, making the influence of the phase's clearance more prominent. Consequently, appropriate values must be found for both clearances within a reasonable range to reduce the impact of the mutual heating on the conductor's temperature.

#### Burial conditions

Finally, burial conditions are a crucial point regarding the current rating of underground power lines. In this sense, two parameters are now analysed: the burial depth (db) and the thermal conductivity of the surrounding medium. Thus, Fig. 24 shows the impact of db on the maximum temperature achieved in the conductors for different clearance values between phases (s). As can be observed, a deeper installation leads to the hottest cables. However, this influence may be partially neutralized by choosing a suitable clearance between phases (in Fig. 24



Fig. 20. Dimensions of the concrete duct bank for the case study.



Fig. 21. Maximum temperature of the conductors in a concrete duct bank (reference case study) (phase current of 883 A).



**Fig. 22.** Maximum temperature of the conductors in a concrete duct bank (trefoil configuration) (phase current of 883 A).

Max. temperature	Ref. conf.	Trefoil	Ref. conf. (concr.)	Trefoil (concr.)
$T_{A1}(^{\circ}C)$	83.34	85.09	81.22	82.81
$T_{B1}(^{\circ}C)$	90	90.22	86.80	87.06
<i>T</i> <sub>C1</sub> (°C)	85.33	84.38	82.83	82.17
<i>T</i> <sub>A2</sub> (°C)	90.06	90.35	87.02	87.17
<i>T<sub>B2</sub></i> (°C)	82.44	84.38	80.61	82.09
<i>T</i> <sub>C2</sub> (°C)	86.45	85.16	84.04	82.85
I <sub>max</sub> (A)	883	880	903	900

**Table 5.** Summary of phase temperatures and ampacity for different phase arrangements. Significant values are in bold.



**Fig. 23.** Influence of the clearance between phases and circuits in the conductor's maximum temperature (phase current of 883 A).

the same maximum temperature is obtained for db = 1 m, s = 0.2 m, and db = 1.5 m, s = 0.4 m) together with the clearance between circuits, as observed in the previous section.

Regarding the thermal conductivity of the surrounding medium, it is important to take into account its dependence on the moisture content since the heat flux caused by the power cables reduces the moisture content in the vicinity of the cables, resulting in a dried-out zone with worse thermal properties<sup>11</sup>. This is typically considered in the IEC 60287 standard<sup>2</sup> through a certain value for the soil temperature (critical temperature) that delimits the change in the soil thermal conductivity. This can be modeled in COMSOL through a variable thermal conductivity as a function of its temperature<sup>14</sup>, as shown in Fig. 25, where the thermal conductivity ranges from 1 to 0.4 W/(m K) when considering a critical temperature of about 50 °C.

The results obtained when considering this variable thermal conductivity for the soil are shown in Fig. 26. In this sense, Fig. 26a shows the temperature distribution in conductors and tubes, the isotherms, and the effective thermal conductivity at each location in the surrounding medium. The darkest area shows the dried-out zone







**Fig. 25.** Surrounding medium thermal conductivity as a function of its temperature for considering the soil dryout.





.....

around the conductors, limited by the 50 °C isotherm (red line in Fig. 26a). This worsens the heat dissipation mechanism, hence increasing the maximum temperature achieved in the conductors. In particular, temperatures are higher than those obtained for a constant thermal conductivity of 0.833 W/(m K) (Fig. 18a), even though the variable thermal conductivity of Fig. 25 can reach up to 1 W/(m K).

Conversely, when a concrete block is present (Fig. 26b), the moisture migration phenomenon only occurs out of the concrete block, limited to a minor extension than in the previous case; this way, conductors are surrounded by a favorable thermal medium that facilitates the heat evacuation mechanism, this situation, together

Case	1000 A centered error [%]	1000 A resting error [%]	1250 A centered error [%]	1250 A resting error [%]
Conductor	0.4	0.8	0.4	4
Shield	0.3	2.7	0.5	3
Insulation	3.6	2.9	5	6.6
Pipe outer wall	7.3	5	4	4.1
Pipe internal wall	1.2	4	0	7

 Table 6.
 Values of percentage errors on the different measurement points for different current value.

with the fact that out of the dried-out zone the thermal conductivity is 1 W/(m K), leads to temperatures below

#### Conclusion

In conclusion, the numerical and experimental analysis of the thermal behavior of high-voltage power cables in unfilled ducts is an essential area of research that has significant implications for the sustainability of electrical energy distribution systems. The results of our study indicate that the temperature distribution within the cable is strongly influenced by the position of the duct, its environment, and the thermal properties of the materials used in the construction of the cable. The numerical simulations performed in this study provide a valuable tool for predicting the temperature distribution within the cable. They can be used to optimize the design of highvoltage power cables for use in unfilled ducts. In Table 6, the values of the percentage errors between simulation and experimental data are reported. The reported values highlight that the simulations faithfully reproduce the actual values. The experimental measurements obtained from our study validate the accuracy of the numerical simulations and provide a basis for further investigation into the thermal behavior of high-voltage power cables. Overall, the findings of this study have important implications for the design and operation of high-voltage power cables in unfilled ducts. By improving our understanding of the thermal behavior of these cables, we can develop a more efficient and sustainable electrical energy distribution infrastructure that can meet the growing demand for electricity while minimizing environmental impact. Future research in this area should focus on developing more accurate and efficient numerical models for predicting the temperature distribution within high-voltage power cables and exploring new materials and designs that can improve their thermal performance.

#### Data availability

All data generated or analysed during this study are included in this published article.

Received: 16 February 2024; Accepted: 27 August 2024 Published online: 04 September 2024

those derived using a constant thermal conductivity (Fig. 21).

#### References

- Enescu, D., Colella, P. & Russo, A. Thermal assessment of power cables and impacts on cable current rating: An overview. *Energies* 13, 5319. https://doi.org/10.3390/en13205319 (2020).
- Calculation of the Continuous Current Rating of Cables (100% Load Factor), IEC Std. 60287 (1969, 1982, 1994), 1994-1995, 1st ed. 1969, 2nd ed. 1982, 3rd ed.
- 3. Hwang, C. C. & Jiang, Y. H. Extensions to the finite element method for thermal analysis of underground cable systems. *Elsevier Electr. Power Syst. Res.* 64, 159–164 (2003).
- Zhang, L. et al. Temperature analysis based on multi-coupling field and ampacity optimization calculation of shore power cable considering tide effect. *IEEE Access* 8, 119785–119794. https://doi.org/10.1109/ACCESS.2020.3005305 (2020).
- Ashfaq, A. et al. Comprehensive analysis of temperature and stress distribution in optical fiber composite low voltage cable using finite element method. *IEEE Access* 8, 217380–217390. https://doi.org/10.1109/ACCESS.2020.3041784 (2020).
- 6. Baazzim, M. S., Al-Saud, M. S. & El-Kady, M. A. Comparison of finite-element and IEC methods for cable thermal analysis under various operating environments. *Int. J. Bioeng. Life Sci.* 8(3), 491–496 (2014).
- Czapp, S., Szultka, S. & Tomaszewski, A. CFD-based evaluation of current-carrying capacity of power cables installed in free air. In 2017 18th International Scientific Conference on Electric Power Engineering (EPE), 1–6 (2017).
- Makhkamova, I., Taylor, P. C., Bumby, J. R. & Mahkamov, K. CFD analysis of the thermal state of an overhead line conductor. 2008 43rd International Universities Power Engineering Conference, 1–4 https://doi.org/10.1109/UPEC.2008.4651567.10.1109/EPE.2017. 7967271 (2008).
- Sedaghat, A. & de León, F. Thermal analysis of power cables in free air: Evaluation and improvement of the IEC standard ampacity calculations. *IEEE Trans. Power Deliv.* 29(5), 2306–2314. https://doi.org/10.1109/TPWRD.2013.2296912 (2014).
- 10. "Comsol Multiphysics," Comsol AB Group, Heat Transfer Module User's Guide.
- 11. CIGRE. Determination of a value of critical temperature rise for a cable backfill material. *Electra* **145**(1992), 15–29 (1992).
- 12. Anders, G. J., Coates, M. & Chaaban, M. Ampacity calculations for cables in shallow troughs. *IEEE Trans. Power Deliv.* 25(4), 2064–2072 (2010).
- 13. Slaninka, P. Thermal resistance of a cable channel. *Bull. Vuki* **18**(5), 212–221 (1965).
- Mróz, M., Anders, G. J. & Gulski, E. Soil dryout in the vicinity of cables with cyclic load installed in a backfill. *IEEE Trans. Power Deliv.* [SPACE]https://doi.org/10.1109/TPWRD.2022.3211851 (2022).
- 15. Da Silva, F. F. & Bak, C. L. Electromagnetic Transients in Power Cables (Springer, 2013).
- Chatzipanagiotou, P., Chatziathanasiou, V., De Mey, G. & Wiecek, B. Influence of soil humidity on the thermal impedance, time constant and structure function of underground cables: A laboratory experiment. *Appl. Therm. Eng.* 113, 1444–1451 (2017).
- Sedaghat, A., Lu, H., Bokhari, A. & de León, F. Enhanced thermal model of power cables installed in ducts for ampacity calculations. *IEEE Trans. Power Deliv.* 33(5), 2404–2411. https://doi.org/10.1109/TPWRD.2018.2841054 (2018).

- 18. Quan, L., Fu, C., Si, W. & Yang, J., & Wang, Q. Numerical study of heat transfer in underground power cable system. *Energy Procedia* 158, 5317–5322 (2019).
- Naskar, A. K., Bhattacharya, N. K. & Sarkar, D. Transient thermal analysis of underground power cables using two dimensional finite element method. *Microsyst. Technol.* 24, 1279–1293 (2018).
- Fothergill, J. C., Dodd, S. J., Dissado, L. A., Liu, T. & Nilsson, U. H. The measurement of very low conductivity and dielectric loss in XLPE cables: A possible method to detect degradation due to thermal aging. *IEEE Trans. Dielectr. Electr. Insul.* 18(5), 1544–1553 (2011).
- Ocłoń, P., Cisek, P., Pilarczyk, M. & Taler, D. Numerical simulation of heat dissipation processes in underground power cable system situated in thermal backfill and buried in a multilayered soil. *Energy Convers. Manag.* 95, 352–370 (2015).
- Kovac, N., Sarajcev, I. & Poljak, D. Nonlinear-coupled electric-thermal modeling of underground cable systems. *IEEE Trans. Power Deliv.* 21(1), 4–14 (2005).
- 23. Umeda, S. et al. Underground power cable, distribution cable, overhead transmission line, industrial cable and their accessories. *Furukawa Rev.* **32**, 2–20 (2007).
- 24. MacKinlay, R. Managing an aging underground high-voltage cable network. Power Eng. J. 4(6), 271-277 (1990).
- Morishita, Y. Technical trends of high voltage and large capacity underground power cables. *IEEJ Trans. Electr. Electron. Eng.* 2(5), 531–535 (2007).
- Khan, A. A., Malik, N., Al-Arainy, A., & Alghuwainem, S. A review of condition monitoring of underground power cables. In 2012 IEEE International Conference on Condition Monitoring and Diagnosis, 909–912. (IEEE, 2012).
- Bustamante, S. et al. Thermal behaviour of medium-voltage underground cables under high-load operating conditions. Appl. Therm. Eng. 156, 444–452 (2019).
- 28. Ocłoń, P. et al. Multiobjective optimization of underground power cable systems. Energy 215, 119089 (2021).
- da Silva, F. M. F., Bak, C. L., & Wiechowski, W. T. Study of high voltage AC underground cable systems. In Proceedings of the Danish PhD Seminar on Detailed Modelling and Validation of Electrical Components and Systems 2010, 10–15. (Energinet. dk, 2010).
- Gouda, O. E., El Dein, A. Z., Tag-Eldin, E., Lehtonen, M. & Darwish, M. M. Thermal analysis of the influence of harmonics on the current capacity of medium-voltage underground power cables. *Energy Sci. Eng.* 11(10), 3471–3485 (2023).
- Aras, F., Oysu, C. & Yilmaz, G. An assessment of the methods for calculating ampacity of underground power cables. *Electr. Power Components Syst.* 33(12), 1385–1402 (2005).
- Aras, F. & Biçen, Y. Thermal modelling and analysis of high-voltage insulated power cables under transient loads. Comput. Appl. Eng. Educ. 21(3), 516–529 (2013).
- 33. Beale, H. K. Underground cables for high-voltage power transmission, 9. (CEGB Res., 1979).
- Ocłoń, P., Pobędza, J., Walczak, P., Cisek, P. & Vallati, A. Experimental validation of a heat transfer model in underground power cable systems. *Energies* 13(7), 1747 (2020).
- Akbal, B. High voltage underground cable bonding optimisation to prevent cable termination faults in mixed high-voltage lines. IET Gener. Transm. Distrib. 14(20), 4331–4338 (2020).
- Neher, J. H. & McGrath, M. H. The calculation of the temperature rise and load capability of cable systems. AIEE Trans. Part III-Power App. Syst. 76, 752–772 (1957).
- Chen-Zhao, Fu., Si, Wen-Rong., Quan, Lei & Yang, Jian. Numerical study of convection and radiation heat transfer in pipe cable. Math. Probl. Eng. 2018, 5475136. https://doi.org/10.1155/2018/5475136 (2018).
- 38. Kopka, H. & Daly, P. W. A Guide to LaTeX 3rd edn. (Addison-Wesley, 1999).

#### Acknowledgements

The authors would like to thank Be Shielding Srl. for the laboratory test.

#### Author contributions

All authors wrote the manuscriptAll authors reviewed the manuscript.

#### **Competing interests**

The authors declare no competing interests.

#### Additional information

Correspondence and requests for materials should be addressed to M.Q.

Reprints and permissions information is available at www.nature.com/reprints.

**Publisher's note** Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.

**Open Access** This article is licensed under a Creative Commons Attribution 4.0 International License, which permits use, sharing, adaptation, distribution and reproduction in any medium or format, as long as you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons licence, and indicate if changes were made. The images or other third party material in this article are included in the article's Creative Commons licence, unless indicated otherwise in a credit line to the material. If material is not included in the article's Creative Commons licence and your intended use is not permitted by statutory regulation or exceeds the permitted use, you will need to obtain permission directly from the copyright holder. To view a copy of this licence, visit http://creativecommons.org/licenses/by/4.0/.

© The Author(s) 2024